

BRITTANY BUOY 62163, United Kingdom

WMO: 995380

Lat: 47.550N

Lon: 8.470W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	43.5	45.0	30.2	24.4	45.2	32.7	27.1	46.2	43.0	47.9	39.6	49.0	20.1	50	0.760

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	67.0	64.4	66.3	63.6	65.6	62.7	65.4	66.5	64.4	65.7	63.6	65.1	14.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	91.5	66.3	63.7	88.3	65.6	62.8	85.5	65.0	30.3	66.7	29.5	65.9	28.9	65.2	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.3	32.3	29.7	40.9	67.4	1.9	1.2	39.5	68.3	38.4	69.0	37.3	69.7	35.9	70.6		
(5)			37.1	66.0	1.8	1.0	35.8	66.7	34.7	67.3	33.7	67.9	32.4	68.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.2	51.5	49.6	51.0	52.6	55.0	58.8	61.9	63.1	62.3	59.6	55.6	52.9	(6)
(7)		DBStd	5.16	2.71	2.94	2.48	2.05	1.92	2.14	2.07	1.59	2.03	2.61	2.83	2.73	(7)
(8)		HDD50	89	17	39	19	4	0	0	0	0	0	0	2	8	(8)
(9)		HDD65	3222	418	431	434	373	310	185	99	63	84	166	283	376	(9)
(10)		CDD50	2350	63	29	50	81	155	265	368	405	369	299	169	97	(10)
(11)		CDD65	8	0	0	0	0	0	0	2	3	3	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	16.9	20.0	19.2	18.5	16.2	15.3	14.4	14.4	14.2	14.3	17.1	19.0	20.3	(14)
(15)	Precipitation	PrecAvg	36.8	4.4	3.5	3.0	2.2	2.3	2.0	2.1	2.2	2.8	4.1	3.9	4.2	(15)
(16)		PrecMax	42.2	6.7	7.1	5.4	3.9	3.8	4.9	3.7	6.1	5.6	6.9	7.5	8.3	(16)
(17)		PrecMin	31.5	1.0	1.1	0.8	0.5	0.4	0.7	0.6	0.5	0.8	1.7	1.0	1.7	(17)
(18)		PrecStd	2.8	1.6	1.3	1.1	0.9	0.8	1.1	0.8	1.3	1.1	1.4	1.3	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	56.6	56.4	57.5	59.8	65.4	67.4	67.9	68.0	66.4	62.2	59.4	(19)
(20)			MCWB	55.1	53.9	53.1	54.7	57.0	61.6	64.4	65.5	65.6	63.4	59.3	55.9	(20)
(21)		2%	DB	56.6	55.2	55.5	56.6	59.0	63.9	66.4	67.0	66.9	64.8	61.0	58.5	(21)
(22)			MCWB	54.2	52.8	52.7	53.9	56.5	60.7	63.5	64.5	64.4	62.1	58.4	55.6	(22)
(23)		5%	DB	55.9	54.3	54.8	55.9	58.3	62.9	65.6	66.3	66.1	64.0	60.2	57.6	(23)
(24)			MCWB	53.5	51.6	52.1	53.3	55.8	59.7	62.8	63.6	63.4	61.2	57.4	54.6	(24)
(25)		10%	DB	55.1	53.6	54.2	55.4	57.7	61.8	64.9	65.6	65.3	63.3	59.6	56.6	(25)
(26)			MCWB	52.7	50.7	51.5	52.8	55.2	58.8	62.1	62.6	62.5	60.4	56.6	53.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.0	54.7	54.0	55.7	58.2	62.8	65.7	66.5	66.4	63.9	60.3	57.5	(27)
(28)			MADB	56.7	55.8	55.0	56.8	59.0	64.6	66.6	67.3	67.5	65.2	61.2	58.8	(28)
(29)		2%	WB	55.0	53.7	53.6	54.8	57.2	61.4	64.6	65.5	65.2	62.9	59.1	56.4	(29)
(30)			MADB	56.0	55.0	54.9	56.2	58.5	63.3	65.7	66.6	66.5	64.4	60.6	58.1	(30)
(31)		5%	WB	54.3	52.6	52.9	54.0	56.4	60.3	63.7	64.5	64.1	62.1	58.2	55.4	(31)
(32)			MADB	55.6	54.2	54.5	55.6	57.9	62.3	65.1	65.8	65.5	63.7	60.0	57.3	(32)
(33)		10%	WB	53.3	51.3	52.2	53.4	55.6	59.4	62.8	63.5	63.3	61.2	57.1	54.2	(33)
(34)			MADB	55.0	53.4	54.1	55.1	57.3	61.4	64.6	65.2	65.0	63.0	59.3	56.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.5	3.6	3.2	2.6	2.4	2.3	2.5	2.4	3.1	3.4	3.5	(35)	
(36)			MCDBR	3.5	4.2	3.2	2.8	2.6	2.6	2.9	2.5	3.5	3.8	4.1	(36)	
(37)			MCWBR	4.9	5.4	3.9	3.1	3.0	3.2	3.5	4.2	3.3	4.5	5.1	5.6	(37)
(38)		5% WB	MCDDBR	3.2	4.1	3.3	2.6	2.5	2.5	2.5	2.8	2.6	3.3	3.9	4.0	(38)
(39)			MCWBR	5.0	6.0	4.4	3.4	3.1	3.4	3.7	4.8	3.6	4.4	5.5	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.360	0.385	0.389	0.387	0.378	0.383	0.372	0.367	0.364	0.349	0.344	(40)	
(41)		taud	2.354	2.380	2.335	2.355	2.406	2.463	2.461	2.506	2.509	2.466	2.393	2.337	(41)	
(42)		Ebn at Noon	225	252	263	274	279	281	278	277	268	248	224	211	(42)	
(43)		Edh at Noon	23	28	34	36	36	34	34	31	28	25	22	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	342	570	954	1490	1735	1951	1783	1571	1223	744	416	272	(44)	
(45)		RadStd	29	46	82	117	136	186	116	108	82	48	30	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page