

BRITTANY BUOY 62163, United Kingdom

WMO: 995380

Lat: 47.550N

Lon: 8.470W

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	7.2	-1.0	3.5	7.3	0.4	3.9	7.9	19.2	8.8	17.7	9.5	9.0	50	0.760

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	19.5	18.0	19.1	17.5	18.7	17.1	18.6	19.2	18.0	18.7	17.5	18.4	6.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.1	19.0	17.6	12.6	18.7	17.1	12.2	18.3	52.5	19.3	50.8	18.8	49.4	18.4	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	14.4	13.3	DB	4.9	19.7	1.1	0.7	4.2	20.2	3.6	20.6	3.0	20.9	2.2	21.4	(4)
(5)			WB	2.8	18.9	1.0	0.6	2.1	19.3	1.5	19.6	1.0	19.9	0.2	20.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	10.8	9.8	10.6	11.4	12.8	14.9	16.6	17.3	16.8	15.4	13.1	11.6	(6)	
	DBStd	2.87	1.51	1.63	1.38	1.14	1.07	1.19	1.15	0.89	1.13	1.45	1.57	1.52	(7)	
	HDD10.0	49	9	22	11	2	0	0	0	0	0	0	1	4	(8)	
	HDD18.3	1790	232	239	241	207	172	103	55	35	47	92	157	209	(9)	
	CDD10.0	1306	35	16	28	45	86	147	204	225	205	166	94	54	(10)	
	CDD18.3	4	0	0	0	0	0	0	1	2	2	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.5	8.9	8.6	8.3	7.2	6.8	6.5	6.4	6.4	6.4	7.7	8.5	9.1	(14)	
(15) Precipitation	PrecAvg	935	111	90	76	55	58	51	53	57	72	105	100	106	(15)	
	PrecMax	1072	170	180	136	98	96	124	94	154	141	174	190	211	(16)	
	PrecMin	801	26	28	20	13	11	18	14	13	21	44	26	42	(17)	
	PrecStd	71	40	34	28	22	20	27	21	32	29	36	33	41	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	13.7	13.6	14.2	15.5	18.6	19.6	19.9	20.0	19.1	16.8	15.2	(19)	
		MCWB	12.8	12.1	11.7	12.6	13.9	16.5	18.0	18.6	18.7	17.5	15.2	13.3	(20)	
	2%	DB	13.7	12.9	13.1	13.7	15.0	17.7	19.1	19.5	19.4	18.2	16.1	14.7	(21)	
		MCWB	12.3	11.6	11.5	12.2	13.6	15.9	17.5	18.1	18.0	16.7	14.7	13.1	(22)	
	5%	DB	13.3	12.4	12.7	13.3	14.6	17.1	18.7	19.1	18.9	17.8	15.7	14.2	(23)	
		MCWB	12.0	10.9	11.1	11.8	13.2	15.4	17.1	17.6	17.4	16.2	14.1	12.6	(24)	
	10%	DB	12.9	12.0	12.3	13.0	14.3	16.6	18.3	18.7	18.5	17.4	15.3	13.7	(25)	
		MCWB	11.5	10.4	10.8	11.6	12.9	14.9	16.7	17.0	17.0	15.8	13.6	11.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	12.6	12.2	13.2	14.5	17.1	18.7	19.2	19.1	17.7	15.7	14.2	(27)	
		MCDB	13.7	13.2	12.8	13.8	15.0	18.1	19.2	19.6	19.7	18.5	16.2	14.9	(28)	
	2%	WB	12.8	12.0	12.0	12.7	14.0	16.3	18.1	18.6	18.4	17.2	15.1	13.6	(29)	
		MCDB	13.3	12.8	12.7	13.5	14.7	17.4	18.7	19.2	19.1	18.0	15.9	14.5	(30)	
	5%	WB	12.4	11.5	11.6	12.2	13.6	15.7	17.6	18.0	17.8	16.7	14.5	13.0	(31)	
		MCDB	13.1	12.3	12.5	13.1	14.4	16.8	18.4	18.8	18.6	17.6	15.6	14.1	(32)	
	10%	WB	11.8	10.7	11.2	11.9	13.1	15.2	17.1	17.5	17.4	16.2	13.9	12.3	(33)	
		MCDB	12.8	11.9	12.3	12.9	14.0	16.3	18.1	18.5	18.3	17.2	15.2	13.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	1.9	2.0	1.8	1.4	1.3	1.3	1.4	1.4	1.4	1.7	1.9	2.0	(35)	
		MCDBR	1.9	2.3	1.8	1.6	1.4	1.4	1.4	1.6	1.4	1.9	2.1	2.3	(36)	
	5% WB	MCWBR	2.7	3.0	2.2	1.7	1.7	1.8	1.9	2.3	1.8	2.5	2.8	3.1	(37)	
		MCWBR	1.8	2.3	1.9	1.5	1.4	1.4	1.4	1.6	1.4	1.8	2.2	2.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.351	0.360	0.385	0.389	0.387	0.378	0.383	0.372	0.367	0.364	0.349	0.344	(40)	
		taud	2.354	2.380	2.335	2.355	2.406	2.463	2.461	2.506	2.509	2.466	2.393	2.337	(41)	
	Ebn at Noon		710	794	830	864	878	886	875	873	844	782	707	664	(42)	
		Edh at Noon	74	88	107	115	113	107	106	98	89	80	70	67	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.08	1.80	3.01	4.70	5.47	6.15	5.62	4.95	3.85	2.35	1.31	0.86	(44)	
	RadStd		0.09	0.14	0.26	0.37	0.43	0.59	0.36	0.34	0.26	0.15	0.10	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page