

HALIFAX HARBOR BUOY 44258, NS, Canada

WMO: 995390

Lat: 44.500N

Lon: 63.400W

Elev: 3

StdP: 101.29

Time Zone: -4.00 (NAA)

Period: 02-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.4	-10.4	N/A	N/A	N/A	N/A	N/A	N/A	17.5	1.1	16.5	0.6	9.4	300	0.760

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.0	20.3	N/A	19.4	N/A	18.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.7	12.3	DB	-15.4	22.4	2.3	1.9	-17.1	23.8	-18.4	24.9	-19.7	26.0	-21.4	27.4	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-1.2	-2.3	0.0	3.5	7.0	11.3	15.2	16.5	15.2	11.6	6.7	1.8	
	DBStd	7.12	4.55	3.94	3.14	2.06	1.86	2.03	1.80	2.04	1.90	2.81	3.40	4.21	
	HDD10.0	1674	346	343	309	195	96	9	0	0	0	17	105	254	
	HDD18.3	4078	604	576	568	445	352	210	98	63	94	207	348	513	
	CDD10.0	646	0	0	0	0	2	49	161	201	157	68	7	0	
	CDD18.3	7	0	0	0	0	0	0	1	6	1	0	0	0	
	CDH23.3	1	0	0	0	0	0	0	0	1	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	6.2	8.0	7.6	7.1	5.9	5.0	4.7	4.2	4.4	5.5	7.1	7.3	7.7	
Precipitation	PrecAvg	1410	132	108	129	113	111	99	91	77	105	144	146	153	
	PrecMax	1588	211	184	228	201	236	228	214	132	326	262	240	245	
	PrecMin	1110	45	29	45	34	46	34	18	39	29	37	69	75	
	PrecStd	150	40	41	54	34	47	48	49	26	59	55	45	49	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	6.5	7.6	9.6	13.3	17.8	20.5	22.3	22.0	18.3	14.4	12.0	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	7.0	4.7	5.8	8.0	11.5	15.7	18.8	20.7	19.2	17.0	13.2	10.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	6.0	3.5	4.8	6.7	10.3	14.8	18.1	19.9	18.5	16.1	12.2	8.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	5.0	2.6	3.7	6.0	9.4	13.9	17.5	19.3	17.9	15.3	11.4	7.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.1	4.4	3.1	2.8	2.8	2.7	3.0	3.2	3.5	4.1	5.7	
		MCDBR	6.5	5.7	5.1	4.1	4.3	4.5	3.6	3.2	3.2	3.6	4.5	6.5	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.304	0.300	0.326	0.351	0.372	0.402	0.419	0.398	0.356	0.336	0.319	0.299		
	taud	2.483	2.520	2.475	2.448	2.437	2.385	2.362	2.417	2.507	2.555	2.549	2.535		
	Ebn at Noon	822	899	913	912	898	868	848	855	870	844	799	795		
	Edh at Noon	70	80	95	106	111	118	119	109	92	77	66	61		
All-Sky Solar Radiation	RadAvg	1.44	2.35	3.55	4.34	4.96	5.39	5.32	4.99	4.10	2.66	1.54	1.15		
	RadStd	0.11	0.17	0.24	0.35	0.64	0.51	0.39	0.34	0.26	0.27	0.16	0.09		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	+1.16	N/A	N/A	+0.45	N/A	N/A	+55	N/A

Nomenclature: See separate page