

BRENT B STATION 63105, United KingdomWMO: **995440**Lat: **61.000N**Lon: **1.692E**Elev: **98**StdP: **14.64**Time Zone: **0.00 (EUW)**Period: **02-14**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.9	33.4	16.6	12.8	35.2	19.4	14.6	36.5	52.7	37.3	50.3	37.3	22.5	40	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	66.1	59.4	64.2	58.8	62.6	57.9	61.3	64.3	59.9	63.1	58.5	61.6	13.5	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.9	77.3	63.0	58.3	72.9	61.7	56.8	69.0	60.3	27.3	64.2	26.4	63.5	25.4	61.7	65.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 48.6	43.1	38.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	42.5	41.8	42.8	45.2	48.5	52.9	57.2	58.5	55.6	49.6	46.7	42.9
	DBStd	6.91	3.67	4.41	4.35	3.68	3.58	3.51	3.50	3.04	3.34	3.63	3.51	4.60
	HDD50	1296	234	231	224	148	71	11	0	0	2	51	105	219
	HDD65	5950	699	651	687	595	512	364	245	204	282	478	549	684
	CDD50	825	0	0	2	3	25	96	222	262	170	37	7	1
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	19.4	23.9	22.6	21.4	18.4	16.8	14.8	15.6	15.3	18.8	20.5	22.6	22.4
Precipitation	PrecAvg	52.8	6.3	5.2	5.0	2.8	1.9	2.6	3.2	3.9	4.6	5.6	5.5	6.1
	PrecMax	65.0	9.9	10.1	9.3	4.8	3.3	5.2	6.0	6.4	7.5	8.5	8.7	9.4
	PrecMin	37.6	3.0	2.3	1.8	1.0	0.9	1.0	1.6	2.6	1.9	2.3	1.7	2.6
	PrecStd	6.5	1.9	2.1	1.8	0.9	0.6	0.9	0.9	1.0	1.3	1.6	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	51.3	53.6	56.2	62.6	65.9	69.9	69.6	65.7	59.2	55.6	52.1
		MCWB	46.5	48.0	48.8	48.2	53.3	56.8	61.9	60.5	58.4	53.7	51.4	48.9
	2%	DB	49.4	49.4	51.4	52.2	57.4	62.6	66.1	66.2	62.9	56.9	52.8	50.9
		MCWB	46.2	46.4	47.3	46.9	50.2	55.9	59.7	60.0	57.1	52.9	50.2	48.1
	5%	DB	48.4	48.5	49.6	50.4	54.9	59.5	64.0	64.3	61.0	55.5	51.7	50.0
		MCWB	45.3	45.7	45.7	46.3	49.3	53.4	58.8	59.6	56.4	51.6	49.1	47.4
	10%	DB	47.6	47.5	48.0	49.3	53.1	57.0	62.1	62.6	59.8	54.3	50.9	49.0
		MCWB	44.4	44.6	44.5	45.8	48.6	52.1	58.0	58.4	55.8	50.6	48.3	45.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	49.1	49.6	50.1	54.3	59.0	62.8	62.8	60.0	56.1	52.8	50.4
		MCDB	49.6	50.4	52.9	53.5	59.2	64.3	66.8	65.7	63.1	57.9	54.4	51.1
	2%	WB	47.4	47.6	47.9	48.3	52.0	56.1	61.1	61.7	58.5	53.7	50.9	49.2
		MCDB	48.8	48.8	50.8	50.5	55.5	61.0	64.4	64.5	61.1	55.7	52.2	50.5
	5%	WB	45.9	46.6	46.3	47.4	50.4	54.3	59.9	60.5	57.6	52.4	50.0	47.8
		MCDB	47.9	48.2	48.9	49.6	53.4	57.8	63.2	63.5	60.1	54.8	51.3	49.8
	10%	WB	44.8	45.1	45.0	46.5	49.2	53.3	58.3	58.8	56.7	51.2	49.0	46.2
		MCDB	47.4	47.1	47.7	48.8	51.9	56.1	61.7	61.9	59.3	53.9	50.7	48.6
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.0	5.7	5.7	6.3	5.8	5.6	5.6	5.3	4.9	5.1	5.1
		MCDBR	5.5	5.6	7.3	7.5	10.0	9.9	9.3	8.8	7.3	6.7	6.2	5.7
		MCWBR	6.4	5.6	6.5	5.6	6.6	6.1	5.5	5.5	5.1	5.7	6.4	7.0
	5% WB	MCDBR	5.5	5.2	6.4	6.9	8.4	8.0	7.9	7.4	5.9	5.5	6.1	6.1
		MCWBR	6.9	5.5	6.3	5.9	6.4	5.7	5.2	5.6	4.7	5.6	6.4	7.8
Clear-Sky Solar Irradiance	taub	0.334	0.355	0.368	0.380	0.370	0.362	0.380	0.370	0.364	0.346	0.321	0.388	
	taud	2.067	2.191	2.271	2.307	2.409	2.471	2.437	2.463	2.432	2.311	2.133	2.322	
	Ebn at Noon	111	190	235	257	271	275	266	259	238	193	116	71	
	Edh at Noon	14	23	29	34	33	31	32	29	25	20	13	9	
All-Sky Solar Radiation	RadAvg	62	219	580	1129	1573	1604	1454	1159	704	331	97	39	
	RadStd	8	28	64	93	110	173	129	106	55	40	12	3	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	N/A	+1.17	+1.12	N/A	N/A	N/A	N/A	-184	-241	N/A	N/A

Nomenclature: See separate page