

CANAVERAL BUOY 41009, FL, USA

WMO: 995450

Lat: 28.508N

Lon: 80.185W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	11.5	0.6	3.9	11.9	2.6	4.5	13.6	15.4	15.3	14.5	14.7	9.7	310	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	29.8	25.7	29.4	25.5	29.1	25.3	26.8	28.7	26.4	28.6	26.1	28.4	4.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	28.4	25.7	21.0	28.3	25.4	20.5	28.2	83.5	28.8	82.0	28.6	80.7	28.5	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.7	11.7	10.7	7.4	30.5	2.4	0.7	5.7	31.0	4.3	31.4	2.9	31.8	1.2	32.4		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	19.0	19.3	20.4	22.6	24.7	26.5	27.3	27.7	27.3	25.7	22.8	20.7
	DBStd	3.79	3.34	3.10	2.60	1.78	1.24	1.07	0.92	0.87	0.95	1.63	2.39	3.35
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	1
	HDD18.3	94	33	24	14	1	0	0	0	0	0	0	3	19
	CDD10.0	5002	279	262	323	377	456	495	538	549	518	486	386	334
	CDD18.3	2053	54	53	78	128	197	245	279	291	268	228	138	94
	CDH23.3	15966	26	18	43	279	1153	2365	3023	3371	2984	1926	572	205
	CDH26.7	2869	0	0	0	0	12	309	678	958	713	193	6	0
Wind	WSAvg	5.9	6.9	6.6	6.6	6.1	5.5	4.9	4.5	4.5	5.2	6.2	7.0	6.8
Precipitation	PrecAvg	1279	61	56	78	60	86	178	163	184	170	125	57	59
	PrecMax	1807	144	191	337	153	344	334	266	449	338	341	221	235
	PrecMin	947	0	7	0	9	14	17	53	41	90	20	7	15
	PrecStd	223	36	38	75	33	66	69	63	76	63	73	48	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.8	24.5	24.8	26.1	27.7	29.8	30.1	30.3	29.7	29.3	27.4	25.8
		MCWB	21.4	21.7	21.5	22.7	23.9	26.0	26.0	25.8	25.4	25.2	23.7	21.9
	2%	DB	24.1	24.0	24.3	25.6	26.9	29.1	29.6	29.9	29.3	28.5	26.8	25.4
		MCWB	20.8	21.4	20.9	22.3	23.5	25.6	25.7	25.7	25.0	24.5	23.2	22.1
	5%	DB	23.5	23.5	23.9	25.2	26.7	28.6	29.1	29.6	29.0	28.0	26.3	25.0
		MCWB	20.3	20.9	20.5	22.0	23.3	25.3	25.5	25.6	24.8	23.9	22.7	21.7
	10%	DB	23.0	23.0	23.4	24.8	26.4	28.1	28.9	29.2	28.8	27.7	25.8	24.6
		MCWB	19.7	20.3	20.1	21.4	23.1	25.0	25.3	25.4	24.6	23.6	21.8	21.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	22.7	22.5	24.1	25.2	27.0	27.3	27.3	26.8	26.0	24.7	23.6
		MCDB	24.0	24.0	24.0	25.5	26.5	28.8	28.8	29.0	28.8	28.9	26.6	25.2
	2%	WB	21.7	22.1	21.8	23.4	24.8	26.4	26.7	26.8	26.2	25.3	24.1	23.2
		MCDB	23.7	23.7	23.6	25.1	26.2	28.4	28.6	28.8	28.7	28.0	26.4	25.1
	5%	WB	21.0	21.7	21.3	22.8	24.4	26.0	26.3	26.4	25.8	25.0	23.7	22.6
		MCDB	23.1	23.4	23.2	24.8	26.0	28.1	28.4	28.6	28.5	27.8	26.2	24.7
	10%	WB	20.3	21.2	20.6	22.3	23.9	25.6	26.0	26.1	25.4	24.4	22.9	21.9
		MCDB	22.7	23.0	22.9	24.4	25.8	27.8	28.2	28.5	28.3	27.3	25.8	24.3
Mean Daily Temperature Range	5% DB	MDBR	3.4	3.3	2.7	2.3	2.0	2.2	2.4	2.4	2.0	2.0	2.4	3.0
		MCDBR	2.8	2.5	2.6	2.3	2.3	2.5	2.5	2.5	2.2	2.1	2.2	2.2
		MCWBR	3.2	2.5	2.8	2.5	2.1	2.2	2.0	2.0	2.0	1.8	2.2	2.4
	5% WB	MCDBR	3.1	2.2	2.7	2.1	2.3	2.6	2.2	2.4	2.1	2.2	2.1	2.6
		MCWBR	3.6	2.5	3.0	2.6	2.1	2.3	2.0	2.1	2.1	2.1	2.4	2.9
Clear-Sky Solar Irradiance	taub	0.352	0.363	0.377	0.400	0.430	0.455	0.470	0.461	0.428	0.403	0.367	0.357	
	taud	2.547	2.527	2.480	2.393	2.351	2.356	2.313	2.352	2.432	2.472	2.524	2.557	
	Ebn at Noon	891	908	914	897	866	839	825	831	852	854	865	867	
	Edh at Noon	88	97	108	121	126	125	130	124	112	101	90	84	
All-Sky Solar Radiation	RadAvg	3.29	4.03	5.13	6.15	6.40	6.16	6.13	5.82	5.02	4.37	3.51	3.01	
	RadStd	0.25	0.28	0.35	0.24	0.46	0.60	0.34	0.33	0.35	0.31	0.20	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-46	+150	+111

Nomenclature: See separate page