

CANAVERAL EAST BUOY 41010, USA

WMO: 995460

Lat: 28.878N

Lon: 78.485W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 13.0	(c) 14.4	(d) 3.8	(e) 5.0	(f) 14.1	(g) 5.0	(h) 5.4	(i) 15.0	(j) 16.0	(k) 16.7	(l) 15.1	(m) 17.9	(n) 9.3	(o) 300	(p) 0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.0	(c) 29.7	(d) 25.6	(e) 29.4	(f) 25.4	(g) 29.1	(h) 25.3	(i) 26.7	(j) 28.8	(k) 26.3	(l) 28.6	(m) 26.1	(n) 28.5	(o) 4.3	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.2	28.5	25.6	20.8	28.4	25.2	20.4	28.2	82.9	28.9	81.5	28.6	80.3	28.5	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.3	(b) 13.0	(c) 11.1	(e) 10.7	(f) 30.2	(g) 1.4	(h) 0.8	(i) 9.7	(j) 30.7	(k) 8.9	(l) 31.2	(m) 8.1	(n) 31.6	(o) 7.1	(p) 32.1		
			DB													
			WB													
				7.2	27.0	1.2	0.6	6.4	27.4	5.6	27.8	5.0	28.1	4.1	28.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	20.0	20.1	21.1	22.4	24.5	26.4	27.6	28.0	27.3	25.6	23.0	21.5
	DBStd	3.35	2.64	2.50	2.06	1.61	1.22	1.11	0.99	0.89	0.83	1.48	1.99	2.49
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	41	16	13	5	1	0	0	0	0	0	1	7	
	CDD10.0	5101	311	282	343	373	450	492	546	557	519	483	389	357
	CDD18.3	2099	68	61	89	123	192	242	287	298	269	225	141	104
	CDH23.3	16396	44	24	70	227	1046	2359	3341	3636	3034	1870	535	209
	CDH26.7	3317	0	0	0	0	8	312	933	1195	717	149	4	0
Wind	WSAvg	6.1	7.2	7.2	6.9	6.3	5.5	5.1	4.9	4.9	5.3	6.3	6.8	6.9
Precipitation	PrecAvg	1103	79	69	77	65	67	120	96	124	147	116	73	70
	PrecMax	1529	217	143	181	172	186	349	169	238	314	316	205	209
	PrecMin	663	22	9	11	20	7	31	20	25	33	24	18	19
	PrecStd	202	50	34	45	32	42	80	41	56	76	79	47	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	24.6	25.2	26.3	27.4	29.2	29.9	30.2	29.7	29.1	27.2	25.9
		MCWB	22.1	22.0	23.1	23.5	24.1	25.2	25.7	25.7	25.3	25.3	23.7	23.0
	2%	DB	24.4	24.1	24.6	25.6	26.9	28.9	29.5	29.9	29.1	28.4	26.7	25.5
		MCWB	21.7	21.6	22.4	22.7	23.8	25.2	25.5	25.7	25.0	25.0	23.5	22.7
	5%	DB	23.9	23.6	24.2	25.1	26.6	28.5	29.1	29.6	28.9	27.9	26.3	25.1
		MCWB	21.1	21.0	21.9	22.1	23.7	25.1	25.4	25.6	24.9	24.3	23.1	22.2
	10%	DB	23.4	23.1	23.7	24.6	26.3	28.1	29.0	29.3	28.6	27.5	25.7	24.5
		MCWB	20.4	20.3	21.1	21.6	23.4	24.9	25.3	25.4	24.8	23.7	22.1	21.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	23.0	24.1	24.2	25.4	26.8	26.9	27.3	26.6	26.1	25.2	24.0
		MCDB	24.6	24.0	24.7	26.1	26.7	28.2	29.1	29.0	28.4	28.4	26.4	25.4
	2%	WB	22.2	22.5	23.3	23.4	24.8	26.3	26.4	26.8	26.1	25.5	24.5	23.4
		MCDB	24.2	23.9	24.5	25.2	26.3	27.9	28.6	29.0	28.3	27.9	26.4	25.2
	5%	WB	21.5	21.8	22.6	22.7	24.3	25.8	26.2	26.4	25.8	25.1	23.8	22.9
		MCDB	23.6	23.6	24.1	24.7	26.1	27.8	28.6	28.9	28.2	27.6	26.2	25.0
	10%	WB	20.7	21.0	21.7	22.2	23.8	25.6	25.8	26.1	25.6	24.5	22.9	22.3
		MCDB	23.0	23.0	23.7	24.3	25.9	27.8	28.5	28.8	28.2	27.2	25.7	24.6
Mean Daily Temperature Range	5% DB	MDBR	2.7	2.7	2.2	1.9	1.5	1.8	1.8	2.0	1.8	1.7	2.1	2.3
		MCDBR	2.9	2.8	2.7	2.4	1.8	1.8	1.7	1.9	2.1	2.1	2.3	2.5
		MCWBR	3.7	4.2	3.5	3.2	2.0	1.7	1.5	1.6	1.8	1.9	2.5	3.0
	5% WB	MCDBR	3.0	3.0	2.7	2.3	1.4	1.8	1.8	2.1	2.0	1.8	2.1	2.5
MCWBR		4.0	4.3	3.7	3.2	2.1	2.0	1.8	1.9	1.9	2.0	2.9	3.2	
Clear-Sky Solar Irradiance	taub	0.361	0.372	0.380	0.402	0.436	0.449	0.461	0.452	0.421	0.401	0.367	0.360	
	taud	2.523	2.507	2.476	2.381	2.334	2.374	2.356	2.392	2.453	2.482	2.533	2.556	
	Ebn at Noon	877	898	910	895	860	843	832	839	858	855	863	862	
	Edh at Noon	90	99	108	122	129	123	125	120	109	100	88	84	
All-Sky Solar Radiation	RadAvg	3.12	3.98	5.13	6.22	6.68	6.42	6.10	5.88	5.09	4.42	3.52	2.95	
	RadStd	0.29	0.38	0.43	0.28	0.47	0.62	0.54	0.47	0.34	0.34	0.23	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page