

PENSACOLA BUOY 42039, USA

WMO: 995470

Lat: 28.788N

Lon: 86.008W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (W06)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.4	49.4	32.6	27.1	50.8	34.9	29.7	51.6	34.2	58.5	32.5	57.3	18.8	350	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	86.9	79.3	86.3	79.0	85.8	78.7	81.3	84.8	80.4	84.4	80.0	84.2	7.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.2	156.9	84.1	79.3	152.1	83.6	78.5	148.0	83.3	44.8	84.9	44.0	84.6	43.4	84.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
30.8	26.3	24.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			41.6	87.7	3.6	1.0	39.0	88.4	36.9	89.0	34.9	89.5	32.3	90.2
			37.5	82.6	3.0	1.5	35.3	83.7	33.6	84.6	31.9	85.5	29.8	86.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.3	62.1	63.2	66.1	70.8	76.0	81.1	82.7	83.2	81.4	76.6	69.8	65.8
	DBStd	8.68	6.68	5.82	4.88	3.82	2.88	2.12	1.76	1.95	1.97	3.99	5.35	6.09
	HDD50	6	5	1	0	0	0	0	0	0	0	0	0	0
	HDD65	365	131	91	47	7	0	0	0	0	0	1	21	67
	CDD50	8509	381	370	501	624	805	934	1013	1031	942	824	595	489
	CDD65	3394	42	41	82	181	340	484	548	566	492	360	167	91
	CDH74	29952	1	11	19	258	1872	5249	6722	7217	5518	2526	449	110
CDH80	8086	0	0	0	0	0	45	1218	2328	2808	1460	226	1	0
Wind	WSAvg	12.7	15.5	14.4	13.8	12.6	11.1	9.2	9.3	9.6	12.5	13.6	15.5	15.8
Precipitation	PrecAvg	53.7	4.3	4.0	5.0	4.2	2.6	5.4	5.7	6.5	5.5	3.8	3.1	3.5
	PrecMax	71.2	11.5	10.4	10.7	9.2	8.4	15.4	12.0	12.4	12.7	9.8	8.2	8.7
	PrecMin	35.0	0.4	0.6	0.2	0.4	0.2	1.5	2.6	2.6	1.7	0.6	0.7	1.3
	PrecStd	9.1	2.5	2.2	2.8	2.3	1.7	3.4	2.0	2.4	2.8	2.2	1.9	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.9	75.7	76.1	78.5	82.4	86.3	87.2	88.4	86.2	84.4	80.2	78.9
		MCWB	72.3	72.2	73.4	74.3	76.5	78.7	80.1	79.5	77.7	78.3	75.1	74.9
	2%	DB	72.5	73.8	74.3	77.5	81.3	85.5	86.4	87.3	85.3	83.5	79.2	77.1
		MCWB	70.7	71.1	72.0	73.9	76.2	79.2	79.3	79.4	77.4	77.8	75.5	74.1
	5%	DB	71.5	72.0	73.2	76.7	80.4	84.8	85.9	86.6	84.6	82.3	78.0	75.2
		MCWB	69.5	70.4	70.9	72.9	75.5	78.7	78.9	79.1	77.3	76.9	73.6	72.8
	10%	DB	70.7	70.6	72.1	75.7	79.7	84.2	85.3	86.2	84.2	81.4	76.7	73.7
		MCWB	68.4	69.0	69.8	71.7	74.9	78.2	78.5	79.0	77.2	76.1	71.8	70.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	73.1	74.8	77.0	79.5	82.4	82.4	82.4	81.2	79.7	77.7	75.6
		MCDB	73.6	74.5	75.2	77.5	80.8	84.8	85.6	86.0	83.5	82.0	79.0	77.0
	2%	WB	71.3	71.9	73.0	75.5	77.7	81.0	80.7	81.2	80.2	79.0	76.7	75.0
		MCDB	72.0	73.0	73.5	76.5	78.8	84.1	84.9	85.3	83.2	81.6	78.5	76.4
	5%	WB	70.2	70.8	71.7	74.3	77.0	79.9	80.2	80.4	79.4	78.3	75.0	73.9
		MCDB	71.2	71.9	72.4	75.4	78.5	83.5	84.6	85.0	83.0	81.3	77.6	75.5
	10%	WB	68.8	69.3	70.4	73.0	76.2	79.1	79.5	80.0	78.7	77.4	72.9	71.9
		MCDB	70.3	70.5	71.4	74.3	78.2	83.0	84.3	84.8	82.9	80.8	76.1	73.6
Mean Daily Temperature Range	5% DB	MDBR	6.2	5.8	4.6	3.7	2.8	3.0	3.6	3.8	3.4	3.5	5.2	5.8
		MCDBR	5.5	5.2	4.5	3.9	2.7	3.2	3.6	3.6	3.7	3.3	5.2	5.2
		MCWBR	7.5	7.1	6.1	5.2	3.4	3.3	3.5	3.0	3.3	3.7	6.9	6.6
	5% WB	MCDBR	5.4	5.0	5.2	4.7	2.5	3.1	3.9	3.9	3.4	3.2	5.3	5.0
		MCWBR	7.9	6.8	7.0	6.0	3.5	3.8	4.3	3.6	3.6	4.4	7.3	6.7
Clear-Sky Solar Irradiance	taub	0.360	0.369	0.374	0.403	0.429	0.448	0.469	0.464	0.431	0.396	0.368	0.358	
	taud	2.503	2.489	2.467	2.391	2.351	2.363	2.311	2.336	2.401	2.473	2.498	2.529	
	Ebn at Noon	279	286	290	284	275	268	262	263	269	272	273	273	
	Edh at Noon	29	32	35	38	40	39	42	40	36	32	29	27	
All-Sky Solar Radiation	RadAvg	1016	1264	1651	1989	2209	2066	1891	1780	1627	1467	1140	927	
	RadStd	92	144	140	166	126	141	120	111	119	100	101	81	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+256	+169

Nomenclature: See separate page