

EAST SCOTIA SLOPE BUOY 44137, Canada

WMO: 995480

Lat: 42.260N

Lon: 62.000W

Elev: 3

StdP: 101.29

Time Zone: -4.00 (W04)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.2	-1.9	N/A	N/A	N/A	N/A	N/A	N/A	20.3	5.3	19.0	4.8	9.8	310	0.632

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	25.4	N/A	24.6	N/A	23.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	16.0	14.4	DB	-5.3	24.8	1.9	0.9	-6.6	25.5	-7.7	26.0	-8.7	26.6	-10.1	27.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	5.8	4.8	5.6	7.4	11.2	15.1	19.9	21.3	19.5	15.4	11.9	8.5
	DBStd	6.54	3.66	3.98	3.87	2.90	3.40	3.10	2.35	1.79	2.39	2.98	3.61	3.80
	HDD10.0	641	136	151	144	88	25	1	0	0	0	1	21	74
	HDD18.3	2442	388	378	394	327	223	107	10	1	15	100	194	304
	CDD10.0	1462	7	6	8	11	62	152	308	349	286	167	78	28
	CDD18.3	222	0	0	0	0	2	9	59	92	51	8	1	0
	CDH23.3	257	0	0	0	0	2	17	84	117	37	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	1	0	0	0
Wind	WSAvg	6.9	8.5	8.5	8.5	6.8	6.0	5.6	4.8	4.8	5.6	7.1	8.3	8.7
Precipitation	PrecAvg	2152	219	195	165	169	142	148	164	177	183	203	178	209
	PrecMax	2498	324	354	225	259	306	269	409	302	722	383	332	317
	PrecMin	1668	76	106	84	54	53	17	83	51	46	82	66	85
	PrecStd	224	58	53	40	50	66	67	63	67	138	78	65	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	17.6	17.0	17.6	23.4	25.1	26.6	26.0	25.6	22.7	21.1	19.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	14.9	15.4	15.5	15.9	19.4	23.3	25.4	25.3	24.6	21.7	19.9	17.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.3	13.7	13.8	14.0	17.6	21.1	24.2	24.6	23.6	20.8	18.6	15.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	11.5	11.2	11.6	12.0	16.2	19.6	23.3	23.9	22.8	19.8	17.3	14.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.7	4.7	3.5	2.8	2.6	2.2	2.2	2.4	3.1	4.2	5.3
		MCDBR	8.9	9.4	7.8	6.0	4.5	3.1	2.4	2.6	3.0	4.2	5.8	7.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.337	0.330	0.346	0.375	0.387	0.416	0.431	0.401	0.370	0.361	0.339	0.329	
	taud	2.428	2.495	2.466	2.413	2.423	2.368	2.370	2.446	2.499	2.510	2.518	2.468	
	Ebn at Noon	798	877	901	894	888	860	842	859	864	828	795	775	
	Edh at Noon	79	85	99	112	114	120	119	107	95	84	72	70	
All-Sky Solar Radiation	RadAvg	1.22	1.98	3.30	4.49	5.24	5.80	5.55	5.23	4.32	2.78	1.67	1.11	
	RadStd	0.14	0.18	0.37	0.38	0.50	0.56	0.44	0.35	0.33	0.27	0.20	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page