

BANQUREAU BANKS BUOY 44139, NL, Canada

WMO: 995500

Lat: 44.240N

Lon: 57.100W

Elev: 10

StdP: 14.69

Time Zone: -4.00 (W04)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.2	19.0	N/A	N/A	N/A	N/A	N/A	N/A	45.5	35.2	42.6	37.4	20.3	310	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	71.0	N/A	69.7	N/A	68.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.7	34.5	31.2	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	34.5	31.9	32.8	38.2	43.2	50.5	60.8	64.6	61.5	54.4	47.0	39.8
	DBStd	12.29	6.78	6.41	6.52	4.65	4.26	4.00	4.39	3.21	3.83	4.36	5.35	5.95
	HDD50	2585	482	508	532	355	217	40	0	0	0	12	121	318
	HDD65	6742	946	928	997	804	676	434	143	47	116	329	541	781
	CDD50	1375	1	0	0	1	6	56	334	453	344	148	30	2
	CDD65	55	0	0	0	0	0	0	11	34	10	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	15.1	20.3	20.0	18.5	13.2	12.0	11.8	11.1	11.5	12.9	14.9	16.4	18.6
(15) Precipitation	PrecAvg	64.6	6.9	5.2	4.5	3.6	3.9	4.6	5.2	5.4	4.8	6.3	7.0	7.5
	PrecMax	78.6	10.1	8.6	6.7	6.2	7.2	8.2	14.2	11.4	13.0	15.0	11.4	11.0
	PrecMin	53.0	4.3	2.4	2.0	1.3	1.5	1.0	1.8	1.8	0.4	1.9	3.6	4.3
	PrecStd	6.5	1.4	1.5	1.2	1.3	1.6	1.9	3.2	2.4	2.6	2.9	2.3	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	48.9	49.5	55.9	58.2	62.3	71.7	72.7	71.4	65.4	61.2	56.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	48.9	46.2	46.4	49.9	53.8	59.5	69.9	71.5	69.6	63.6	59.0	52.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	45.9	43.5	43.9	47.5	51.1	57.6	68.2	70.4	68.1	61.9	56.9	50.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	43.2	40.9	41.3	45.2	49.0	56.0	66.5	69.2	66.6	60.4	54.8	48.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.9	7.5	5.1	4.7	4.1	3.7	3.5	4.2	4.9	6.2	7.9
		MCDBR	14.4	14.7	11.8	7.4	6.2	5.6	4.1	4.1	5.5	7.0	8.9	11.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.332	0.327	0.347	0.379	0.382	0.406	0.437	0.399	0.379	0.361	0.336	0.322
	taud		2.411	2.480	2.442	2.381	2.419	2.381	2.340	2.438	2.472	2.486	2.496	2.458
	Ebn at Noon		248	274	282	281	282	274	264	271	268	258	246	241
	Edh at Noon		24	27	31	36	36	37	39	34	30	26	22	21
(44) All-Sky Solar Radiation	RadAvg		357	580	1003	1376	1634	1668	1675	1564	1309	821	478	305
	RadStd		25	63	93	108	111	159	141	139	92	60	58	24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page