

BANQUREAU BANKS BUOY 44139, NL, CanadaWMO: **995500**Lat: **44.240N**Lon: **57.100W**Elev: **3**StdP: **101.29**Time Zone: **-4.00 (W04)**Period: **90-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.5	-7.2	N/A	N/A	N/A	N/A	N/A	N/A	20.3	1.8	19.0	3.0	9.1	310	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.9	21.7	N/A	21.0	N/A	20.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.4	13.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	1.4	-0.1	0.5	3.4	6.2	10.3	16.0	18.1	16.4	12.4	8.3	4.3
	DBStd	6.83	3.77	3.56	3.62	2.58	2.37	2.22	2.44	1.78	2.13	2.42	2.97	3.30
	HDD10.0	1436	268	282	296	197	121	22	0	0	0	7	67	177
	HDD18.3	3746	526	516	554	447	376	241	79	26	64	183	301	434
	CDD10.0	764	1	0	0	1	3	31	186	252	191	82	17	1
	CDD18.3	31	0	0	0	0	0	0	6	19	6	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.7	9.1	8.9	8.3	5.9	5.3	5.3	4.9	5.2	5.8	6.7	7.3	8.3
Precipitation	PrecAvg	1642	175	131	114	92	98	117	133	136	121	159	177	190
	PrecMax	1996	256	219	170	157	182	209	361	289	329	382	289	280
	PrecMin	1346	108	61	50	33	37	25	45	46	10	49	91	108
	PrecStd	165	36	39	31	34	40	47	82	62	66	74	58	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	9.4	9.7	13.3	14.6	16.8	22.1	22.6	21.9	18.5	16.2	13.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.4	7.9	8.0	10.0	12.1	15.3	21.1	21.9	20.9	17.6	15.0	11.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	7.7	6.4	6.6	8.6	10.6	14.2	20.1	21.3	20.1	16.6	13.8	10.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	6.2	4.9	5.2	7.3	9.5	13.4	19.2	20.7	19.2	15.8	12.6	9.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.5	4.2	2.8	2.6	2.3	2.0	1.9	2.3	2.7	3.5	4.4
		MCDBR	8.0	8.2	6.5	4.1	3.5	3.1	2.3	2.3	3.1	3.9	5.0	6.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.332	0.327	0.347	0.379	0.382	0.406	0.437	0.399	0.379	0.361	0.336	0.322	
	taud	2.411	2.480	2.442	2.381	2.419	2.381	2.340	2.438	2.472	2.486	2.496	2.458	
	Ebn at Noon	781	865	890	885	889	865	832	855	846	814	776	759	
	Edh at Noon	76	84	99	114	113	118	122	107	96	83	70	66	
All-Sky Solar Radiation	RadAvg	1.12	1.83	3.16	4.34	5.15	5.26	5.28	4.93	4.13	2.59	1.51	0.96	
	RadStd	0.08	0.20	0.29	0.34	0.35	0.50	0.44	0.44	0.29	0.19	0.18	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page