

GASCOGNE BUOY 62001, France

WMO: 995700

Lat: 45.200N

Lon: 5.000W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	42.2	43.9	29.3	23.3	44.0	31.9	26.2	45.0	41.0	51.7	37.9	52.4	18.9	40	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.7	71.0	67.8	70.0	66.7	69.2	65.8	68.5	70.5	67.6	69.6	66.6	68.8	10.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	101.6	70.2	66.6	97.9	69.3	65.6	94.5	68.6	32.8	70.6	32.0	69.8	31.2	68.9	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
34.1	30.8	27.9	39.2	73.6	3.6	3.5	36.6	76.1	34.5	78.1	32.5	80.1	29.9	82.6
			35.6	71.2	3.3	3.1	33.2	73.5	31.3	75.3	29.4	77.1	27.0	79.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual													
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.2	52.0	50.4	52.0	54.0	56.7	61.7	65.3	66.4	65.4	62.2	57.5	54.0
(7)		DBStd	6.26	3.39	3.71	2.66	2.53	2.55	2.55	2.62	1.95	2.30	3.20	3.27	3.27
(8)		HDD50	80	21	35	13	2	0	0	0	0	0	0	1	8
(9)		HDD65	2624	402	409	402	329	259	103	29	8	22	94	225	342
(10)		CDD50	3065	83	46	76	123	207	351	474	507	463	379	226	130
(11)		CDD65	133	0	0	0	0	0	4	37	50	34	8	0	0
(12)		CDH74	10	0	4	0	0	0	0	1	3	1	1	0	0
(13)		CDH80	2	0	2	0	0	0	0	0	0	0	0	0	0
(14)	Wind	WSAvg	14.9	18.3	18.0	16.1	13.8	13.6	12.1	12.3	12.3	12.8	14.5	17.5	17.6
(15)	Precipitation	PrecAvg	29.9	3.6	2.7	2.2	2.2	1.9	1.6	1.5	1.6	2.1	3.3	3.6	3.6
(16)		PrecMax	36.6	7.4	5.0	6.3	4.9	3.6	3.2	2.8	4.3	5.8	5.6	7.6	5.6
(17)		PrecMin	20.7	0.7	0.9	0.2	0.7	0.5	0.2	0.3	0.2	0.2	0.9	1.0	0.7
(18)		PrecStd	3.7	1.8	1.1	1.3	1.1	0.7	0.7	0.7	1.0	1.3	1.4	1.7	1.5
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	59.1	58.5	57.6	60.2	63.3	69.0	72.9	74.2	71.3	69.5	65.5	61.5	
(20)		0.4% MCWB	55.9	54.3	53.6	56.8	59.3	64.6	69.2	71.7	68.2	65.6	61.3	57.1	
(21)		2% DB	57.9	56.3	56.6	59.3	61.9	67.3	71.3	70.8	70.1	68.2	63.8	60.3	
(22)		2% MCWB	54.9	53.0	53.2	56.3	58.4	63.7	68.2	67.6	66.8	64.0	60.2	56.6	
(23)		5% DB	56.8	55.4	55.9	58.5	61.0	66.1	69.9	70.0	69.3	67.2	62.7	59.2	
(24)		5% MCWB	54.0	52.3	52.8	55.5	57.8	62.1	66.6	66.7	66.0	63.2	59.5	55.7	
(25)		10% DB	56.1	54.6	55.3	57.5	60.1	65.1	68.7	69.2	68.5	66.2	61.8	58.2	
(26)		10% MCWB	53.4	51.5	52.4	54.3	56.9	61.2	65.3	65.8	65.2	62.6	58.7	54.8	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	56.7	54.9	54.9	58.4	60.8	66.3	69.9	72.1	69.0	66.8	62.5	58.3	
(28)		0.4% MCDB	58.1	56.8	56.2	59.4	62.2	67.9	72.1	74.1	70.6	68.5	64.0	60.4	
(29)		2% WB	55.8	53.7	54.2	57.4	59.5	64.7	68.4	68.5	68.0	65.5	61.1	57.3	
(30)		2% MCDB	57.1	55.3	55.7	59.0	61.2	66.7	70.7	70.4	69.7	67.5	63.1	59.7	
(31)		5% WB	54.8	52.9	53.6	56.2	58.5	63.3	67.3	67.5	66.8	64.6	60.2	56.3	
(32)		5% MCDB	56.4	54.8	55.4	58.0	60.4	65.5	69.6	69.5	68.7	66.7	62.4	58.7	
(33)		10% WB	54.0	52.2	52.9	55.1	57.5	62.2	66.0	66.6	66.0	63.5	59.2	55.4	
(34)		10% MCDB	55.8	54.4	54.9	57.1	59.5	64.5	68.4	68.8	68.1	65.7	61.5	57.8	
(35)	Mean Daily Temperature Range	MDBR	3.6	4.1	3.1	2.8	2.6	2.5	2.5	2.7	2.8	3.6	3.7	3.6	
(36)		5% DB MCDBR	3.8	5.1	3.2	3.1	3.3	3.1	2.8	3.2	3.5	4.8	4.8	4.1	
(37)		5% WB MCWBR	4.3	4.9	3.2	2.9	3.6	3.4	3.6	4.1	3.6	4.9	5.0	4.3	
(38)		5% WB MCDBR	3.4	4.4	3.0	2.8	3.3	3.0	2.8	3.2	3.5	4.2	4.3	4.0	
(39)	Clear-Sky Solar Irradiance	taub	0.343	0.353	0.378	0.388	0.394	0.400	0.390	0.384	0.375	0.369	0.351	0.338	
(40)		taud	2.443	2.429	2.376	2.366	2.390	2.404	2.437	2.467	2.479	2.480	2.440	2.430	
(41)		Ebn at Noon	241	262	270	277	278	276	277	275	268	253	235	229	
(42)		Edh at Noon	23	28	33	36	37	36	35	33	30	26	23	21	
(43)	All-Sky Solar Radiation	RadAvg	394	666	1099	1601	1885	2022	1990	1748	1386	846	484	352	
(44)		RadStd	30	75	116	134	120	150	88	109	71	59	40	29	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page