

GASCOGNE BUOY 62001, France

WMO: 995700

Lat: 45.200N

Lon: 5.000W

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.7	6.6	-1.5	3.3	6.7	-0.1	3.7	7.2	18.4	10.9	16.9	11.3	8.5	40	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.5	21.7	19.9	21.1	19.3	20.7	18.8	20.3	21.4	19.8	20.9	19.2	20.4	4.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	21.2	19.2	14.0	20.7	18.7	13.5	20.3	58.3	21.5	56.5	21.0	54.8	20.5	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.2	13.8	12.5	DB	4.0	23.1	2.0	1.9	2.6	24.5	1.4	25.6	0.3	26.7	-1.2	28.1	(4)
(5)			WB	2.0	21.8	1.8	1.7	0.7	23.0	-0.4	24.1	-1.4	25.0	-2.8	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	11.1	10.2	11.1	12.2	13.7	16.5	18.5	19.1	18.6	16.8	14.2	12.2	(6)	
	DBStd	3.48	1.88	2.06	1.48	1.41	1.41	1.42	1.46	1.08	1.28	1.78	1.82	1.82	(7)	
	HDD10.0	44	12	19	7	1	0	0	0	0	0	0	1	4	(8)	
	HDD18.3	1458	223	227	223	183	144	57	16	4	12	52	125	190	(9)	
	CDD10.0	1703	46	26	42	68	115	195	263	282	257	211	126	72	(10)	
	CDD18.3	74	0	0	0	0	0	2	21	28	19	4	0	0	(11)	
	CDH23.3	6	0	2	0	0	0	0	1	2	1	1	0	0	(12)	
	CDH26.7	1	0	1	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.7	8.2	8.1	7.2	6.2	6.1	5.4	5.5	5.5	5.7	6.5	7.8	7.9	(14)	
(15) Precipitation	PrecAvg	760	91	68	57	55	48	40	39	40	54	84	92	92	(15)	
	PrecMax	930	188	128	159	125	91	82	71	108	148	142	194	142	(16)	
	PrecMin	527	18	22	6	17	13	6	8	4	4	24	25	18	(17)	
	PrecStd	93	46	29	32	29	18	19	18	25	33	35	42	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	14.7	14.2	15.7	17.4	20.5	22.7	23.5	21.8	20.8	18.6	16.4	(19)	
		MCWB	13.3	12.4	12.0	13.8	15.2	18.1	20.7	22.1	20.1	18.7	16.3	13.9	(20)	
	2%	DB	14.4	13.5	13.7	15.2	16.6	19.6	21.8	21.6	21.2	20.1	17.7	15.7	(21)	
		MCWB	12.7	11.7	11.8	13.5	14.7	17.6	20.1	19.8	19.3	17.8	15.7	13.7	(22)	
	5%	DB	13.8	13.0	13.3	14.7	16.1	18.9	21.1	21.1	20.7	19.6	17.1	15.1	(23)	
		MCWB	12.2	11.3	11.5	13.1	14.3	16.7	19.2	19.3	18.9	17.3	15.3	13.2	(24)	
	10%	DB	13.4	12.5	12.9	14.2	15.6	18.4	20.4	20.7	20.3	19.0	16.6	14.5	(25)	
		MCWB	11.9	10.8	11.3	12.4	13.8	16.2	18.5	18.8	18.5	17.0	14.8	12.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	12.7	12.7	14.7	16.0	19.0	21.0	22.3	20.6	19.4	17.0	14.6	(27)	
		MCDB	14.5	13.8	13.4	15.2	16.8	19.9	22.3	23.4	21.5	20.3	17.8	15.8	(28)	
	2%	WB	13.2	12.1	12.3	14.1	15.3	18.2	20.2	20.3	20.0	18.6	16.2	14.1	(29)	
		MCDB	14.0	12.9	13.2	15.0	16.2	19.3	21.5	21.3	20.9	19.7	17.3	15.4	(30)	
	5%	WB	12.7	11.6	12.0	13.4	14.7	17.4	19.6	19.7	19.3	18.1	15.7	13.5	(31)	
		MCDB	13.5	12.7	13.0	14.4	15.8	18.6	20.9	20.8	20.4	19.3	16.9	14.8	(32)	
	10%	WB	12.2	11.2	11.6	12.8	14.2	16.8	18.9	19.2	18.9	17.5	15.1	13.0	(33)	
		MCDB	13.2	12.4	12.7	13.9	15.3	18.1	20.2	20.5	20.1	18.7	16.4	14.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.0	2.3	1.7	1.6	1.5	1.4	1.4	1.5	1.5	2.0	2.1	2.0	(35)	
		MCDBR	2.1	2.8	1.8	1.7	1.8	1.7	1.6	1.8	1.9	2.7	2.7	2.3	(36)	
	5% WB	MCWBR	2.4	2.7	1.8	1.6	2.0	1.9	2.0	2.3	2.0	2.7	2.8	2.4	(37)	
		MCWBR	1.9	2.5	1.6	1.6	1.9	1.6	1.5	1.8	1.9	2.3	2.4	2.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.343	0.353	0.378	0.388	0.394	0.400	0.390	0.384	0.375	0.369	0.351	0.338	(40)	
		taud	2.443	2.429	2.376	2.366	2.390	2.404	2.437	2.467	2.479	2.480	2.440	2.430	(41)	
	Ebn at Noon	Ebn at Noon	759	825	851	873	876	870	874	867	846	797	740	721	(42)	
		Edh at Noon	73	88	105	115	116	115	110	103	94	83	72	67	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.24	2.10	3.46	5.05	5.94	6.38	6.27	5.51	4.37	2.67	1.53	1.11	(44)	
	RadStd	RadStd	0.10	0.23	0.37	0.42	0.38	0.47	0.28	0.34	0.22	0.18	0.13	0.09	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page