

NORTH SEA STATION 62112, United Kingdom

WMO: 995730

Lat: 58.700N

Lon: 1.300E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 90-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.2	34.8	N/A	N/A	N/A	N/A	N/A	N/A	50.5	39.7	46.6	40.4	25.3	120	0.897

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	66.4	N/A	64.2	N/A	62.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.9	40.8	35.7	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	42.5	41.4	43.1	44.6	48.5	52.9	57.6	59.0	55.1	49.6	46.3	43.5		
	DBStd	6.70	3.25	3.77	3.22	3.05	3.12	2.85	3.14	3.36	3.18	3.16	3.00	3.05		
	HDD50	1288	233	241	214	164	65	6	0	0	3	45	114	203		
	HDD65	5948	698	661	678	613	511	362	232	188	298	479	560	668		
	CDD50	818	0	0	1	1	19	94	234	279	155	32	3	0		
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	18.5	21.9	22.8	21.6	17.9	15.5	15.5	13.4	14.0	16.8	20.2	21.6	21.6		
	PrecAvg	49.4	5.9	5.0	4.6	2.5	1.9	2.5	3.0	3.6	4.4	5.0	5.3	5.7		
(15) Precipitation	PrecMax	61.4	8.5	10.4	8.2	4.1	3.6	4.1	5.3	9.1	6.5	8.8	7.2	11.4		
	PrecMin	38.0	2.4	2.4	2.2	1.7	0.8	1.1	1.3	1.5	1.6	1.9	2.5	2.9		
	PrecStd	6.0	1.9	1.9	1.5	0.7	0.6	0.7	0.9	1.3	1.3	1.6	1.3	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	50.1	53.0	54.3	58.5	63.1	69.3	69.7	64.8	58.1	53.6	51.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	49.0	48.4	49.7	51.4	55.7	60.3	65.6	67.2	61.3	55.8	52.2	50.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	47.8	47.4	48.3	49.8	54.0	58.4	63.6	65.3	60.1	54.3	51.4	48.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	46.9	46.3	47.2	48.4	52.8	56.8	61.8	63.6	59.0	53.2	50.4	47.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.1	5.6	5.9	6.0	6.2	6.1	5.5	5.3	4.6	4.6	5.1		
		MCDBR	5.4	5.7	6.8	7.8	8.4	8.7	8.6	8.1	6.8	5.2	5.2	6.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.338	0.355	0.370	0.388	0.374	0.374	0.387	0.382	0.369	0.354	0.334	0.312		
	taud		2.132	2.233	2.291	2.292	2.408	2.442	2.419	2.434	2.441	2.332	2.196	2.098		
	Ebn at Noon		141	205	242	259	272	273	266	259	243	205	143	108		
	Edh at Noon		16	24	30	35	33	33	33	30	26	22	15	12		
(44) All-Sky Solar Radiation	RadAvg		99	286	679	1213	1694	1664	1543	1251	800	394	141	63		
	RadStd		10	39	45	115	115	126	141	85	64	26	14	7		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page