

NORTH SEA STATION 62119, United Kingdom

WMO: 995740

Lat: 57.000N

Lon: 2.000E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (E00)

Period: 04-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.3	34.0	18.4	13.9	34.4	21.0	15.7	36.0	43.2	41.5	40.8	42.8	18.9	110	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	67.4	62.7	65.5	61.4	63.8	59.8	63.9	66.0	61.9	63.8	60.6	62.7	11.2	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	85.5	65.5	60.9	80.0	63.3	59.4	75.7	61.9	29.2	66.7	27.7	64.0	26.8	62.8	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 41.6	36.6	32.7		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	42.8	41.8	42.6	45.6	49.8	54.4	59.0	60.0	57.3	53.1	48.4	44.8	(6)
	DBStd	7.30	3.59	3.45	4.11	3.28	4.02	3.69	3.95	3.04	3.00	3.20	3.34	4.16	(7)
	HDD50	1116	222	231	231	136	52	6	0	0	0	9	65	164	(8)
	HDD65	5485	687	651	695	582	471	319	194	159	232	369	499	627	(9)
	CDD50	1118	0	0	1	4	46	137	278	308	218	106	17	3	(10)
	CDD65	8	0	0	0	0	0	0	6	2	0	0	0	0	(11)
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	16.8	21.4	18.7	17.4	14.6	14.4	12.7	12.7	13.9	15.9	18.7	19.8	21.0	(14)
(15) Precipitation	PrecAvg	44.6	5.3	4.3	3.9	2.2	1.8	2.5	2.9	3.3	3.8	4.4	5.1	5.2	(15)
	PrecMax	56.1	8.9	7.7	6.8	3.6	3.0	4.3	4.3	6.2	5.9	7.4	7.5	11.6	(16)
	PrecMin	32.8	1.8	2.2	1.6	1.2	0.8	1.3	1.3	1.1	1.8	1.5	2.7	2.6	(17)
	PrecStd	5.6	1.9	1.5	1.2	0.7	0.5	0.7	0.8	1.0	1.1	1.4	1.2	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.1	49.5	52.7	56.7	64.3	66.0	72.1	69.0	65.5	61.1	56.1	54.2	(19)
		MCWB	47.7	44.6	47.4	50.4	55.0	59.2	66.2	64.2	60.0	54.6	52.4	50.1	(20)
	2%	DB	49.3	47.7	49.4	52.2	59.6	62.6	68.5	66.7	63.3	59.2	54.3	52.0	(21)
		MCWB	46.5	44.2	45.6	48.9	53.6	56.9	63.0	63.5	59.1	54.6	51.9	48.8	(22)
	5%	DB	48.3	46.7	48.0	50.8	56.8	60.4	66.3	65.0	62.1	58.1	53.3	50.7	(23)
		MCWB	45.6	43.6	44.8	48.1	52.0	56.0	61.5	61.8	58.6	54.3	51.0	48.0	(24)
	10%	DB	47.2	45.8	46.8	49.5	54.8	59.0	64.2	63.6	61.1	57.1	52.2	49.6	(25)
		MCWB	44.4	43.0	44.2	47.1	51.1	55.1	60.0	60.5	57.8	53.8	49.9	47.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	46.6	48.2	52.1	56.8	60.2	66.5	66.2	62.4	57.4	53.9	50.4	(27)
		MCDB	49.4	48.0	50.8	53.1	63.7	64.5	71.1	67.0	63.2	59.2	54.7	51.5	(28)
	2%	WB	46.8	45.4	46.7	50.4	54.3	57.8	63.1	64.5	60.5	56.2	52.7	49.3	(29)
		MCDB	48.0	46.8	48.8	52.0	58.1	61.0	66.1	66.2	61.8	57.9	53.7	50.8	(30)
	5%	WB	45.7	44.4	45.7	49.1	53.1	56.6	61.4	62.8	59.0	55.1	51.6	48.3	(31)
		MCDB	47.2	46.0	47.7	50.7	56.4	59.6	64.2	64.3	60.6	56.8	52.8	50.1	(32)
	10%	WB	44.5	43.4	44.7	47.8	51.5	55.3	60.0	61.1	57.9	53.6	50.4	46.9	(33)
		MCDB	46.4	45.2	46.6	49.5	54.8	58.3	62.5	62.9	59.8	55.5	51.8	49.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.1	5.1	5.7	5.9	5.6	5.3	5.0	4.9	4.7	5.0	5.6	(35)
		MCDBR	5.9	5.8	6.3	7.5	9.6	8.6	8.4	7.3	6.3	6.5	6.1	6.7	(36)
	5% WB	MCWBR	6.1	5.3	4.8	5.4	5.6	5.0	5.2	5.0	4.7	5.6	6.0	6.9	(37)
		MCWBR	5.2	5.0	5.6	7.5	9.2	7.6	7.4	5.6	5.3	5.5	5.9	6.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.334	0.351	0.370	0.395	0.378	0.383	0.389	0.388	0.375	0.353	0.335	0.313	(40)
		taud	2.196	2.281	2.305	2.279	2.407	2.420	2.413	2.422	2.436	2.381	2.252	2.176	(41)
	Ebn at Noon		163	217	247	259	273	272	267	260	245	216	162	136	(42)
		Edh at Noon	18	24	30	36	34	34	33	31	27	22	16	14	(43)
(44) All-Sky Solar Radiation	RadAvg		127	326	736	1278	1757	1751	1636	1338	889	449	174	89	(44)
	RadStd		14	46	62	96	115	120	164	91	96	32	19	11	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page