

NORTH SEA STATION 62119, United Kingdom

WMO: 995740

Lat: 57.000N

Lon: 2.000E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (E00)

Period: 04-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.2	1.1	-7.6	2.0	1.3	-6.1	2.2	2.2	19.3	5.3	18.3	6.0	8.5	110	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	19.7	17.1	18.6	16.3	17.6	15.5	17.7	18.9	16.6	17.7	15.9	17.0	5.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.2	18.6	16.1	11.4	17.4	15.2	10.8	16.6	50.0	19.3	46.7	17.8	44.5	17.1	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.4	14.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	6.0	5.4	5.9	7.5	9.9	12.4	15.0	15.5	14.0	11.7	9.1	7.1		
	DBStd	4.05	2.00	1.92	2.28	1.82	2.23	2.05	2.20	1.69	1.67	1.78	1.85	2.31		
	HDD10.0	620	123	128	128	76	29	3	0	0	0	5	36	91		
	HDD18.3	3047	382	362	386	323	262	177	108	88	129	205	277	348		
	CDD10.0	621	0	0	1	2	26	76	154	171	121	59	9	2		
	CDD18.3	4	0	0	0	0	0	0	3	1	0	0	0	0		
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	7.5	9.6	8.4	7.8	6.5	6.4	5.7	5.7	6.2	7.1	8.4	8.9	9.4		
(15) Precipitation	PrecAvg	1132	134	110	98	55	46	64	73	85	97	111	129	131		
	PrecMax	1426	226	196	173	91	75	108	108	157	151	187	190	295		
	PrecMin	834	46	56	40	30	21	34	33	28	45	39	69	65		
	PrecStd	142	49	39	30	17	13	18	21	25	27	36	31	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	9.7	11.5	13.7	17.9	18.9	22.3	20.5	18.6	16.2	13.4	12.4		
		MCWB	8.7	7.0	8.6	10.2	12.8	15.1	19.0	17.9	15.6	12.6	11.3	10.1		
	2%	DB	9.6	8.7	9.7	11.2	15.3	17.0	20.3	19.3	17.4	15.1	12.4	11.1		
		MCWB	8.1	6.8	7.6	9.4	12.0	13.8	17.2	17.5	15.1	12.6	11.0	9.4		
	5%	DB	9.0	8.2	8.9	10.5	13.8	15.8	19.1	18.3	16.7	14.5	11.8	10.4		
		MCWB	7.5	6.5	7.1	8.9	11.1	13.3	16.4	16.6	14.8	12.4	10.6	8.9		
	10%	DB	8.5	7.7	8.2	9.7	12.6	15.0	17.9	17.6	16.2	13.9	11.2	9.8		
		MCWB	6.9	6.1	6.8	8.4	10.6	12.8	15.5	15.8	14.4	12.1	10.0	8.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	8.1	9.0	11.2	13.8	15.7	19.2	19.0	16.9	14.1	12.2	10.2		
		MCDB	9.6	8.9	10.5	11.7	17.6	18.1	21.7	19.4	17.3	15.1	12.6	10.8		
	2%	WB	8.2	7.4	8.1	10.2	12.4	14.3	17.3	18.0	15.8	13.4	11.5	9.6		
		MCDB	8.9	8.2	9.3	11.1	14.5	16.1	19.0	19.0	16.5	14.4	12.1	10.5		
	5%	WB	7.6	6.9	7.6	9.5	11.7	13.7	16.3	17.1	15.0	12.8	10.9	9.0		
		MCDB	8.4	7.8	8.7	10.4	13.6	15.3	17.9	17.9	15.9	13.8	11.5	10.1		
	10%	WB	7.0	6.3	7.1	8.8	10.9	12.9	15.5	16.2	14.4	12.0	10.2	8.3		
		MCDB	8.0	7.3	8.1	9.7	12.7	14.6	16.9	17.1	15.4	13.0	11.0	9.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	2.8	2.8	3.2	3.3	3.1	3.0	2.8	2.7	2.6	2.8	3.1		
		MCDBR	3.3	3.2	3.5	4.2	5.3	4.8	4.7	4.0	3.5	3.6	3.4	3.7		
	5% WB	MCWBR	3.4	3.0	2.7	3.0	3.1	2.8	2.9	2.8	2.6	3.1	3.3	3.8		
		MCWBR	2.9	2.8	3.1	4.2	5.1	4.2	4.1	3.1	3.0	3.0	3.3	3.5		
(40) Clear-Sky Solar Irradiance	taub	taub	0.334	0.351	0.370	0.395	0.378	0.383	0.389	0.388	0.375	0.353	0.335	0.313		
		taud	2.196	2.281	2.305	2.279	2.407	2.420	2.413	2.422	2.436	2.381	2.252	2.176		
	Ebn at Noon	Ebn at Noon	513	685	779	817	860	859	843	819	772	680	512	430		
		Edh at Noon	56	77	96	114	107	107	105	98	84	69	52	43		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.40	1.03	2.32	4.03	5.54	5.52	5.16	4.22	2.80	1.41	0.55	0.28		
	RadStd	RadStd	0.04	0.14	0.19	0.30	0.36	0.38	0.52	0.29	0.30	0.10	0.06	0.03		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page