

NORTH SEA STATION 62142, United Kingdom

WMO: 995850

Lat: 53.000N

Lon: 2.100E

Elev: 98

StdP: 14.64

Time Zone: 0.00 (EUW)

Period: 02-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.3	33.7	N/A	N/A	N/A	N/A	N/A	N/A	43.2	40.9	37.0	45.8	17.5	80	0.787

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.3	72.6	N/A	69.4	N/A	67.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.5	32.8	29.8	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	41.8	40.4	42.5	46.5	51.3	56.6	62.2	63.6	60.8	55.3	49.5	43.9		
	DBStd	8.87	3.92	4.08	3.86	4.05	3.59	3.82	3.63	3.38	3.92	3.80	3.21	3.83		
	HDD50	1147	255	270	234	119	28	1	0	0	0	5	46	189		
	HDD65	5072	720	690	699	556	426	253	103	68	136	302	466	653		
	CDD50	1604	0	0	0	13	67	199	379	422	324	168	30	2		
	CDD65	56	0	0	0	0	0	1	18	26	11	0	0	0		
	CDH74	69	0	0	0	0	0	2	23	33	10	1	0	0		
	CDH80	7	0	0	0	0	0	0	2	5	0	0	0	0		
(14) Wind	WSAvg	16.2	19.2	17.3	16.6	14.9	15.1	13.2	13.1	13.8	15.3	17.4	19.0	19.3		
(15) Precipitation	PrecAvg	29.8	2.9	2.2	2.0	1.8	2.0	2.3	2.4	2.6	2.4	2.8	3.2	3.1		
	PrecMax	35.5	4.9	3.7	3.8	5.0	4.8	5.6	3.9	5.4	4.8	4.5	4.9	5.0		
	PrecMin	20.7	0.6	0.7	0.3	0.2	0.6	0.5	1.1	0.4	0.7	0.7	1.4	1.5		
	PrecStd	4.1	1.2	0.8	0.9	1.2	0.9	1.4	0.9	1.1	1.1	0.9	0.9	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	50.7	52.5	59.8	63.4	72.2	77.2	79.0	74.8	66.8	58.2	53.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	49.4	48.9	49.5	55.3	58.7	65.7	71.6	72.8	69.2	63.3	56.2	51.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	48.3	46.9	48.0	52.7	56.6	62.6	68.2	69.9	66.7	61.4	54.8	50.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	47.1	45.5	46.8	50.9	55.3	60.5	65.7	67.6	65.0	59.8	53.8	49.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.2	4.7	5.5	5.5	6.7	7.9	7.3	6.1	4.8	4.3	4.3		
		MCDBR	5.5	5.7	6.5	9.6	8.6	11.5	12.8	12.1	9.9	7.1	5.4	4.9		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.330	0.347	0.378	0.402	0.401	0.406	0.409	0.398	0.382	0.361	0.335	0.319		
	taud		2.343	2.377	2.310	2.278	2.351	2.351	2.354	2.395	2.431	2.437	2.390	2.331		
	Ebn at Noon		204	239	254	263	269	269	266	262	252	231	201	184		
	Edh at Noon		19	25	32	38	37	37	36	33	29	23	18	16		
(44) All-Sky Solar Radiation	RadAvg		211	436	838	1363	1687	1769	1702	1435	1019	560	259	161		
	RadStd		20	70	77	130	115	106	169	99	78	45	24	17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (55 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page