

WEST TAMPA BUOY 42036, USA

WMO: 995910

Lat: 28.501N

Lon: 84.516W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (W06)

Period: 01-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	46.3	49.3	31.7	26.1	49.2	34.4	29.1	52.4	30.9	57.2	29.8	58.0	19.0	340	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.7	86.6	78.5	86.2	78.3	85.6	77.9	80.4	84.3	80.0	84.2	79.3	83.9	7.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.7	83.2	78.5	147.8	83.1	77.9	144.9	83.0	44.0	84.4	43.3	84.2	42.7	84.0	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.4	25.8	23.6	DB	42.1	87.7	3.1	1.0	39.9	88.5	38.0	89.1	36.3	89.7	34.0	90.4	(4)
(5)			WB	37.6	81.1	2.1	1.2	36.0	82.0	34.8	82.8	33.6	83.5	32.0	84.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.0	61.7	61.6	65.4	70.2	75.8	80.9	82.7	83.1	81.4	76.9	69.8	65.6	(6)
(7)		DBStd	8.85	6.26	5.10	4.68	3.69	2.98	2.26	1.89	1.79	1.80	3.92	5.12	5.99	(7)
(8)		HDD50	7	5	1	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD65	393	134	114	53	5	0	0	0	0	0	1	19	67	(9)
(10)		CDD50	8392	367	325	476	605	798	927	1013	1027	941	834	594	485	(10)
(11)		CDD65	3304	31	18	64	161	333	477	548	562	491	370	163	86	(11)
(12)		CDH74	29476	0	0	1	202	1744	5087	6732	7103	5446	2705	366	90	(12)
(13)		CDH80	7772	0	0	0	0	32	1128	2341	2687	1348	226	10	0	(13)
(14)	Wind	WSAvg	12.2	14.5	13.6	12.6	11.2	10.1	9.2	8.8	9.9	12.4	13.4	15.3	15.1	(14)
(15)	Precipitation	PrecAvg	57.3	4.1	3.7	4.4	3.4	2.8	7.0	8.3	8.3	6.1	3.5	2.5	3.3	(15)
(16)		PrecMax	66.8	8.7	13.2	9.4	8.3	6.8	15.1	15.6	12.5	16.3	7.2	5.7	10.1	(16)
(17)		PrecMin	42.4	1.3	1.0	0.3	0.9	0.3	1.9	5.0	5.2	1.5	0.6	0.3	1.0	(17)
(18)		PrecStd	7.3	1.9	2.4	2.4	1.7	1.8	2.6	2.4	2.1	3.1	1.9	1.5	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.5	71.5	73.9	78.5	82.0	86.4	87.3	87.8	85.7	84.3	81.3	77.6	(19)
(20)			MCWB	71.3	70.5	71.2	74.9	76.4	78.6	79.1	79.0	77.2	76.1	77.3	73.7	(20)
(21)		2%	DB	71.4	70.4	72.8	77.5	81.0	85.5	86.5	87.0	85.1	83.3	79.8	76.7	(21)
(22)			MCWB	70.0	69.3	70.7	74.7	76.3	78.4	78.5	78.7	77.0	75.8	75.7	73.3	(22)
(23)		5%	DB	70.7	69.4	71.9	76.5	80.2	84.9	86.0	86.4	84.4	82.3	77.7	75.0	(23)
(24)			MCWB	68.9	68.1	69.7	73.6	75.7	78.1	78.3	78.3	76.8	75.4	73.6	72.1	(24)
(25)		10%	DB	69.5	68.4	71.0	75.1	79.5	84.2	85.4	85.9	84.0	81.3	76.0	73.4	(25)
(26)			MCWB	67.2	66.8	68.8	72.0	75.0	77.6	77.9	78.0	76.7	75.0	71.2	70.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.3	71.3	73.1	77.2	78.7	81.3	81.5	81.3	80.4	80.0	78.2	75.3	(27)
(28)			MADB	72.6	71.4	73.2	77.7	80.2	83.8	85.2	85.9	83.1	81.6	80.9	76.8	(28)
(29)		2%	WB	71.1	70.1	71.9	75.6	77.6	80.2	80.4	80.3	79.4	77.4	76.5	74.2	(29)
(30)			MADB	71.3	70.3	72.3	77.0	79.3	83.1	84.9	85.2	83.2	80.8	79.4	75.9	(30)
(31)		5%	WB	69.6	69.0	70.9	74.3	77.0	79.3	79.7	79.7	78.8	76.7	74.9	72.8	(31)
(32)			MADB	70.3	69.3	71.5	75.8	79.0	82.6	84.8	84.9	83.0	80.6	77.7	74.8	(32)
(33)		10%	WB	68.2	67.5	69.6	73.0	76.1	78.5	79.1	79.1	78.1	75.7	72.9	71.1	(33)
(34)			MADB	69.5	68.2	70.5	74.7	78.5	82.3	84.4	84.6	82.8	80.3	75.9	73.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.1	5.8	4.4	3.5	2.8	3.2	3.6	3.7	3.2	3.5	5.0	5.7	(35)
(36)			MCDBR	5.7	5.9	4.0	3.4	2.9	3.2	3.5	3.5	3.4	3.1	4.1	4.7	(36)
(37)			MCWBR	7.3	7.8	5.4	3.6	3.4	2.7	3.0	3.1	3.3	3.5	5.1	5.8	(37)
(38)		5% WB	MCDBR	4.8	5.2	4.1	3.5	2.6	2.9	3.8	3.8	3.6	3.4	4.2	5.2	(38)
(39)			MCWBR	6.3	7.1	5.8	4.3	3.6	3.3	3.5	3.7	3.9	3.9	5.7	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.361	0.366	0.372	0.394	0.424	0.448	0.470	0.460	0.430	0.397	0.367	0.355	(40)	
(41)		taud	2.497	2.494	2.470	2.405	2.360	2.371	2.310	2.354	2.412	2.476	2.504	2.540	(41)	
(42)		Ebn at Noon	279	287	291	286	276	268	262	264	270	273	274	275	(42)	
(43)		Edh at Noon	30	32	35	38	40	39	42	39	36	32	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1059	1290	1699	2052	2241	2068	1939	1805	1620	1496	1184	972	(44)	
(45)		RadStd	93	125	158	151	127	144	96	103	140	92	95	86	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.72	N/A	N/A	+0.67	N/A	N/A	N/A	N/A	+247	+184

Nomenclature: See separate page