

CLIPPER STATION 62144, United Kingdom

WMO: 995940

Lat: 53.400N

Lon: 1.700E

Elev: 98

StdP: 14.64

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.2	34.7	N/A	N/A	N/A	N/A	N/A	N/A	44.0	44.1	39.7	44.7	18.3	60	0.754

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	68.4	N/A	66.8	N/A	65.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.2	33.1	29.9	DB	31.9	73.9	2.2	2.6	30.3	75.7	29.0	77.2	27.8	78.7	26.2	80.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	42.7	41.3	43.2	47.1	51.6	56.4	61.1	61.8	59.4	54.6	50.1	44.9
	DBStd	7.95	3.52	3.73	4.12	3.94	3.63	3.72	3.33	2.68	3.06	3.54	3.31	3.95
	HDD50	1019	228	244	210	103	25	2	0	0	0	7	37	163
	HDD65	5039	693	664	675	537	416	257	128	105	169	324	447	624
	CDD50	1473	0	0	1	17	75	195	344	365	282	149	41	4
	CDD65	13	0	0	0	0	0	0	6	5	1	1	0	0
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.3	19.0	16.6	15.9	13.6	14.0	11.9	11.9	12.6	14.1	16.1	18.1	19.4
Precipitation	PrecAvg	29.8	2.9	2.2	2.0	1.8	2.0	2.3	2.4	2.6	2.4	2.8	3.2	3.1
	PrecMax	35.5	4.9	3.7	3.8	5.0	4.8	5.6	3.9	5.4	4.8	4.5	4.9	5.0
	PrecMin	20.7	0.6	0.7	0.3	0.2	0.6	0.5	1.1	0.4	0.7	0.7	1.4	1.5
	PrecStd	4.1	1.2	0.8	0.9	1.2	0.9	1.4	0.9	1.1	1.1	0.9	0.9	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.4	50.4	53.1	59.8	62.1	67.5	71.8	70.9	68.1	66.1	59.0	54.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	50.0	48.6	51.0	56.1	59.2	64.2	68.8	68.2	66.3	62.1	57.2	52.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	48.5	47.3	49.6	54.0	57.4	62.4	66.8	66.6	65.0	60.1	55.8	51.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	47.2	46.1	48.3	52.1	56.0	60.9	65.5	65.5	63.7	58.7	54.6	50.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.5	5.2	5.6	5.5	5.8	6.2	5.2	4.9	4.6	4.3	4.5
		MCDBR	5.7	5.3	6.9	8.4	7.8	8.6	8.6	7.0	6.6	6.0	5.2	5.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.331	0.347	0.377	0.402	0.398	0.405	0.408	0.397	0.381	0.359	0.333	0.318	
	taud	2.340	2.376	2.315	2.278	2.363	2.357	2.359	2.401	2.434	2.444	2.387	2.321	
	Ebn at Noon	200	238	254	262	270	269	266	262	251	231	199	180	
	Edh at Noon	19	25	32	37	36	37	36	33	28	23	18	16	
All-Sky Solar Radiation	RadAvg	203	426	826	1322	1662	1721	1664	1411	1003	554	255	157	
	RadStd	20	64	70	128	122	112	144	95	82	39	23	16	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page