

K2 BUOY 62081, United Kingdom

WMO: 996050

Lat: 51.000N

Lon: 13.300W

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.9	6.7	-0.8	3.5	7.2	0.3	3.9	7.7	19.6	8.8	18.4	9.1	10.7	280	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	17.9	16.8	17.4	16.3	17.1	16.0	17.3	17.6	16.7	17.2	16.3	16.9	6.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.2	17.6	16.5	11.8	17.1	16.1	11.4	16.8	48.7	17.8	47.1	17.3	45.8	17.0	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.5	14.3	DB	4.4	18.4	1.4	1.2	3.3	19.2	2.5	19.9	1.7	20.6	0.7	21.4	(4)
(5)			WB	2.8	17.7	1.0	0.9	2.1	18.3	1.5	18.8	1.0	19.3	0.3	20.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	10.3	9.9	10.1	10.8	11.7	13.7	15.1	15.6	15.3	13.8	11.8	10.7	(6)	
	DBStd	2.50	1.59	1.63	1.65	1.43	1.17	1.31	1.20	0.89	1.09	1.45	1.55	1.73	(7)	
	HDD10.0	75	15	19	17	6	1	0	0	0	0	0	4	13	(8)	
	HDD18.3	2157	248	235	257	225	204	138	101	86	92	140	196	236	(9)	
	CDD10.0	959	25	17	19	32	55	112	158	173	158	118	58	35	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.0	10.2	9.3	8.9	7.2	7.4	6.6	6.1	6.9	7.4	8.4	8.1	9.9	(14)	
(15) Precipitation	PrecAvg	1146	127	107	88	69	67	66	76	84	91	121	120	131	(15)	
	PrecMax	1371	201	211	134	112	139	102	132	161	171	220	199	247	(16)	
	PrecMin	883	29	34	41	27	28	28	39	36	30	37	74	54	(17)	
	PrecStd	109	40	42	22	22	24	19	26	29	34	42	35	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.7	14.5	16.3	19.7	15.0	17.0	18.8	18.3	18.0	17.1	15.6	15.0	(19)	
		MCWB	13.8	13.6	14.9	18.0	13.5	15.6	17.6	17.2	16.9	16.2	14.2	13.9	(20)	
	2%	DB	13.9	13.4	14.7	14.8	14.1	16.2	17.9	17.7	17.6	16.6	14.8	14.2	(21)	
		MCWB	13.0	12.3	13.8	13.8	12.8	14.8	16.7	16.6	16.5	15.6	13.5	13.0	(22)	
	5%	DB	13.1	12.4	12.5	13.2	13.7	15.8	17.3	17.2	17.2	16.2	14.4	13.4	(23)	
		MCWB	12.1	11.3	11.2	12.0	12.5	14.4	16.2	16.1	16.2	15.0	13.1	12.2	(24)	
	10%	DB	12.5	12.0	11.9	12.5	13.3	15.3	16.8	16.9	16.9	15.8	13.9	12.9	(25)	
		MCWB	11.4	10.8	10.7	11.2	12.1	14.1	15.6	15.6	15.8	14.5	12.7	11.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	13.7	15.1	17.8	14.2	16.6	18.0	17.7	17.6	16.6	14.7	14.4	(27)	
		MCDB	14.5	14.4	15.7	19.8	14.7	17.0	18.5	17.9	17.7	16.8	15.1	14.8	(28)	
	2%	WB	13.2	12.5	13.8	14.0	13.2	15.4	17.2	17.2	16.9	16.0	14.1	13.3	(29)	
		MCDB	13.7	13.1	14.7	14.9	13.7	15.8	17.6	17.5	17.2	16.5	14.6	13.8	(30)	
	5%	WB	12.3	11.6	11.7	12.4	12.9	14.9	16.6	16.6	16.6	15.4	13.6	12.6	(31)	
		MCDB	12.8	12.2	12.2	13.1	13.4	15.5	17.1	17.1	17.0	16.0	14.2	13.2	(32)	
	10%	WB	11.7	11.1	11.1	11.7	12.6	14.4	16.0	16.1	16.2	14.9	13.0	12.0	(33)	
		MCDB	12.3	11.9	11.8	12.5	13.2	15.1	16.7	16.7	16.8	15.6	13.8	12.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.4	2.1	2.1	1.8	1.4	1.6	1.5	1.4	1.5	1.7	2.1	2.3	(35)	
		MCDBR	3.1	2.7	2.9	2.7	1.6	2.7	2.1	1.6	1.6	1.6	2.2	2.8	(36)	
	5% WB	MCWBR	4.1	3.5	3.9	3.3	2.0	2.8	2.1	2.4	2.4	2.3	3.1	3.7	(37)	
		MCWBR	2.9	2.5	2.9	2.7	1.5	2.3	1.6	1.7	1.6	1.6	2.2	2.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.365	0.367	0.384	0.385	0.395	0.376	0.380	0.370	0.369	0.364	0.354	0.360	(40)	
		taud	2.221	2.305	2.310	2.360	2.375	2.467	2.467	2.507	2.492	2.409	2.284	2.189	(41)	
	Edn at Noon	Edn at Noon	617	746	808	856	862	880	871	863	823	744	630	550	(42)	
		Edh at Noon	75	88	105	111	115	105	104	95	87	79	69	66	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.80	1.47	2.69	4.26	5.14	5.58	5.11	4.47	3.29	1.94	0.97	0.60	(44)	
	RadStd	RadStd	0.08	0.12	0.20	0.26	0.31	0.52	0.43	0.31	0.24	0.13	0.08	0.04	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page