

NICE BUOY 61001, France

WMO: 996080

Lat: 43.400N

Lon: 7.800E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	41.6	44.4	21.5	16.2	48.9	25.2	19.3	48.0	43.8	46.7	41.6	47.5	25.0	50	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	81.0	74.2	80.0	73.8	79.0	73.1	75.9	79.5	74.7	78.8	73.7	78.1	6.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.6	129.3	78.9	73.3	124.0	78.1	72.0	118.5	77.2	39.3	79.7	38.2	78.8	37.3	78.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.7	35.0	31.5	39.0	82.4	3.2	2.4	36.7	84.1	34.8	85.6	33.0	86.9	30.6	88.6		
(5)			34.6	76.6	2.4	1.8	32.9	77.9	31.5	78.9	30.2	79.9	28.4	81.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	52.0	50.7	53.6	57.3	62.9	69.4	74.2	74.3	70.0	64.8	59.0	54.5	(6)	(7)
	DBStd	8.90	3.57	3.46	2.84	2.48	3.32	3.95	3.60	3.37	3.06	3.74	3.76	3.74	(7)	(8)
	HDD50	69	22	29	8	0	0	0	0	0	0	0	1	9	(8)	(9)
	HDD65	2034	404	400	353	230	82	7	0	0	3	48	182	325	(9)	(10)
	CDD50	4432	83	49	120	220	400	581	749	754	600	458	269	149	(10)	(11)
	CDD65	924	0	0	0	0	18	138	284	289	153	41	1	0	(11)	(12)
	CDH74	2546	0	0	0	0	1	237	1114	1138	54	2	0	0	(12)	(13)
	CDH80	85	0	0	0	0	0	2	36	47	0	0	0	0	(13)	(14)
(14) Wind	WSAvg	12.7	15.8	16.0	15.5	12.2	10.6	9.3	8.8	8.6	10.5	14.0	15.6	15.6	(14)	(15)
(15) Precipitation	PrecAvg	36.8	3.3	2.2	2.2	3.2	2.5	1.9	1.2	1.4	3.6	5.1	6.3	3.9	(15)	(16)
	PrecMax	59.2	13.0	7.0	9.4	7.4	5.7	5.1	3.5	4.1	10.7	11.5	21.7	9.6	(16)	(17)
	PrecMin	18.3	0.0	0.0	0.0	0.6	0.7	0.2	0.0	0.2	0.1	0.9	0.4	0.1	(17)	(18)
	PrecStd	9.6	3.2	1.9	2.2	2.1	1.4	1.2	0.8	1.0	2.8	3.0	5.1	2.8	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.6	57.6	59.8	64.7	72.5	80.1	82.2	82.8	76.7	72.8	67.3	62.4	(19)	(20)
		MCWB	54.4	49.9	54.1	59.1	66.5	72.5	73.1	74.7	69.7	66.4	61.0	56.8	(20)	(21)
	2%	DB	58.5	56.1	58.5	62.8	70.6	78.7	81.0	81.3	75.4	71.8	65.4	60.8	(21)	(22)
		MCWB	52.5	49.9	53.5	57.6	65.7	72.7	73.2	75.0	69.5	66.0	59.8	55.2	(22)	(23)
	5%	DB	57.3	55.3	57.6	61.7	69.2	77.4	80.0	80.4	74.5	71.0	64.2	59.6	(23)	(24)
		MCWB	51.8	50.0	52.9	57.0	65.0	71.9	73.1	74.9	68.7	65.6	58.5	54.5	(24)	(25)
	10%	DB	56.3	54.6	56.7	60.7	67.5	75.6	79.1	79.2	73.7	70.0	63.3	58.9	(25)	(26)
		MCWB	51.3	49.5	52.3	56.5	63.6	70.4	72.8	73.8	67.9	65.1	57.8	54.0	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.7	53.7	56.5	60.7	68.6	74.7	76.3	77.4	73.4	69.6	63.9	59.0	(27)	(28)
		MCDB	58.2	55.4	58.5	62.7	70.5	78.2	79.3	80.8	75.0	70.7	65.6	61.0	(28)	(29)
	2%	WB	54.3	52.5	55.3	59.4	67.2	73.5	75.1	76.4	72.0	68.2	62.0	57.0	(29)	(30)
		MCDB	56.8	54.9	57.4	61.6	69.6	77.7	79.1	80.1	74.1	70.8	64.4	59.4	(30)	(31)
	5%	WB	53.2	51.5	54.5	58.2	65.6	72.2	74.3	75.5	70.5	66.9	60.2	56.0	(31)	(32)
		MCDB	56.0	54.6	56.7	60.6	68.6	76.5	78.7	79.4	73.5	70.1	62.9	58.9	(32)	(33)
	10%	WB	52.2	50.5	53.7	57.3	63.9	70.6	73.4	74.5	69.2	65.6	59.1	55.2	(33)	(34)
		MCDB	55.5	54.2	56.1	60.0	67.0	74.9	78.3	78.6	72.8	69.0	62.4	58.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.7	3.4	3.4	3.5	3.6	3.5	3.3	3.3	3.4	3.6	3.5	(35)	(36)
		MCDBR	3.7	4.0	3.6	4.1	4.8	4.8	4.2	4.2	3.4	3.8	3.9	3.6	(36)	(37)
	5% WB	MCWBR	4.3	4.4	3.4	3.1	3.6	3.0	3.9	3.7	3.5	3.8	4.4	4.1	(37)	(38)
		MCWBR	3.6	3.5	3.0	3.7	4.4	4.0	3.8	3.6	3.1	3.0	3.4	3.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.335	0.354	0.389	0.420	0.426	0.432	0.427	0.421	0.408	0.395	0.361	0.331	(39)	(40)
		taud	2.474	2.420	2.334	2.268	2.301	2.329	2.350	2.375	2.386	2.397	2.441	2.488	(40)	(41)
	Edn at Noon		252	266	269	268	269	267	267	266	259	246	238	242	(41)	(42)
		Edh at Noon	23	29	36	41	41	40	38	36	33	29	24	21	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		543	825	1256	1654	1985	2278	2297	1999	1502	977	602	476	(43)	(44)
	RadStd		52	92	119	110	135	98	94	74	77	77	54	55	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (23 neighbors)	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page