

NICE BUOY 61001, France

WMO: 996080

Lat: 43.400N

Lon: 7.800E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.3	6.9	-5.8	2.3	9.4	-3.8	2.8	8.9	19.6	8.2	18.6	8.6	11.2	50	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	27.2	23.4	26.7	23.2	26.1	22.8	24.4	26.4	23.7	26.0	23.2	25.6	3.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.6	18.5	26.0	23.0	17.7	25.6	22.2	16.9	25.1	73.5	26.5	71.1	26.0	68.8	25.8	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.7	15.7	14.1	DB	3.9	28.0	1.8	1.3	2.6	29.0	1.5	29.8	0.5	30.5	-0.8	31.5	(4)
(5)			WB	1.5	24.8	1.3	1.0	0.5	25.5	-0.3	26.1	-1.0	26.6	-2.0	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	11.1	10.4	12.0	14.1	17.2	20.8	23.4	23.5	21.1	18.2	15.0	12.5		
	DBStd	4.95	1.98	1.92	1.58	1.38	1.84	2.20	2.00	1.87	1.70	2.08	2.09	2.08		
	HDD10.0	38	12	16	4	0	0	0	0	0	0	0	1	5		
	HDD18.3	1130	224	222	196	128	46	4	0	0	2	27	101	181		
	CDD10.0	2462	46	27	67	122	222	323	416	419	333	254	149	83		
	CDD18.3	513	0	0	0	0	10	77	158	161	85	23	1	0		
	CDH23.3	1414	0	0	0	0	1	132	619	632	30	1	0	0		
	CDH26.7	47	0	0	0	0	0	1	20	26	0	0	0	0		
(14) Wind	WSAvg	5.7	7.1	7.1	7.0	5.5	4.7	4.2	3.9	3.9	4.7	6.3	7.0	7.0		
(15) Precipitation	PrecAvg	934	83	56	56	81	63	49	31	36	91	130	160	98		
	PrecMax	1504	331	178	240	188	146	130	88	104	271	291	551	245		
	PrecMin	464	0	1	0	16	17	4	0	5	3	23	9	2		
	PrecStd	243	82	48	55	54	36	31	21	25	70	77	129	71		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	14.2	15.5	18.2	22.5	26.7	27.9	28.2	24.8	22.7	19.6	16.9		
		MCWB	12.5	10.0	12.3	15.0	19.1	22.5	22.8	23.7	21.0	19.1	16.1	13.8		
	2%	DB	14.7	13.4	14.7	17.1	21.4	25.9	27.2	27.4	24.1	22.1	18.6	16.0		
		MCWB	11.4	10.0	12.0	14.2	18.7	22.6	22.9	23.9	20.8	18.9	15.4	12.9		
	5%	DB	14.1	12.9	14.2	16.5	20.6	25.2	26.7	26.9	23.6	21.7	17.9	15.4		
		MCWB	11.0	10.0	11.6	13.9	18.3	22.2	22.8	23.8	20.4	18.7	14.7	12.5		
	10%	DB	13.5	12.6	13.7	16.0	19.7	24.2	26.1	26.2	23.2	21.1	17.4	15.0		
		MCWB	10.7	9.7	11.3	13.6	17.6	21.3	22.7	23.2	19.9	18.4	14.3	12.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	12.0	13.6	16.0	20.3	23.7	24.6	25.2	23.0	20.9	17.7	15.0		
		MCDB	14.6	13.0	14.7	17.1	21.4	25.7	26.3	27.1	23.9	21.5	18.7	16.1		
	2%	WB	12.4	11.4	13.0	15.2	19.6	23.1	24.0	24.7	22.2	20.1	16.7	13.9		
		MCDB	13.8	12.7	14.1	16.4	20.9	25.4	26.2	26.7	23.4	21.6	18.0	15.2		
	5%	WB	11.8	10.8	12.5	14.5	18.6	22.3	23.5	24.2	21.4	19.4	15.7	13.3		
		MCDB	13.3	12.5	13.7	15.9	20.3	24.7	26.0	26.3	23.0	21.2	17.2	15.0		
	10%	WB	11.2	10.3	12.1	14.1	17.7	21.4	23.0	23.6	20.6	18.7	15.1	12.9		
		MCDB	13.1	12.3	13.4	15.5	19.4	23.9	25.7	25.9	22.7	20.5	16.9	14.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	1.9	2.1	1.9	1.9	2.0	2.0	1.9	1.8	1.9	1.9	2.0	2.0		
		MCDBR	2.0	2.2	2.0	2.3	2.6	2.7	2.3	2.3	1.9	2.1	2.2	2.0		
	5% WB	MCWBR	2.4	2.5	1.9	1.7	2.0	1.7	2.2	2.0	2.0	2.1	2.5	2.3		
		MCWBR	2.0	2.0	1.7	2.1	2.4	2.2	2.1	2.0	1.7	1.7	1.9	1.8		
(40) Clear-Sky Solar Irradiance	taub		0.335	0.354	0.389	0.420	0.426	0.432	0.427	0.421	0.408	0.395	0.361	0.331		
	taud		2.474	2.420	2.334	2.268	2.301	2.329	2.350	2.375	2.386	2.397	2.441	2.488		
	Ebn at Noon		793	837	847	846	849	843	837	818	777	750	762	767		
	Edh at Noon		74	91	112	129	128	125	121	114	105	92	76	67		
(44) All-Sky Solar Radiation	RadAvg		1.71	2.60	3.96	5.21	6.26	7.18	7.24	6.30	4.74	3.08	1.90	1.50		
	RadStd		0.16	0.29	0.37	0.35	0.43	0.31	0.30	0.23	0.24	0.24	0.17	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		+0.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page