

LION BUOY 61002, France

WMO: 996170

Lat: 42.100N

Lon: 4.700E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	40.0	42.7	23.0	17.3	48.6	28.2	22.2	51.6	49.5	45.1	47.2	47.2	38.4	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.7	78.9	74.7	77.7	73.4	76.5	72.2	75.6	77.9	74.6	77.0	73.4	75.9	10.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	129.9	77.3	73.7	125.4	76.5	72.5	120.5	75.5	39.0	78.1	38.1	77.2	37.0	76.0	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.4	40.9	37.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	52.7	50.8	54.0	57.0	61.0	67.5	72.1	72.9	69.9	65.2	58.9	54.1
	DBStd	8.36	3.57	4.50	2.84	2.59	2.64	3.33	3.09	2.68	3.48	4.53	4.33	3.75
	HDD50	82	19	42	7	0	0	0	0	0	0	0	2	12
	HDD65	2079	382	398	340	239	127	14	0	0	3	53	186	337
	CDD50	4246	102	63	132	211	341	524	685	711	598	471	268	140
	CDD65	767	0	0	0	0	3	87	220	246	151	58	2	0
	CDH74	1107	0	0	0	0	0	21	427	510	140	9	0	0
	CDH80	5	0	0	0	0	0	0	4	1	0	0	0	0
(14) Wind	WSAvg	17.3	19.0	20.9	19.1	14.9	16.3	14.0	14.8	14.9	15.7	17.2	20.0	21.3
(15) Precipitation	PrecAvg	31.3	2.3	2.0	2.2	2.7	2.8	2.2	1.8	2.2	3.4	4.0	3.0	2.5
	PrecMax	43.5	7.7	5.5	5.5	6.6	6.2	8.0	3.5	4.4	6.4	8.5	9.1	6.8
	PrecMin	23.3	0.0	0.4	0.1	0.9	0.9	0.4	0.6	0.8	1.0	1.5	0.4	0.3
	PrecStd	5.4	1.8	1.3	1.3	1.5	1.2	1.4	0.7	0.9	1.2	2.1	1.9	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.1	57.7	60.1	64.6	68.3	76.3	80.6	79.9	77.4	75.5	68.4	63.6
		MCWB	54.6	52.9	55.1	60.5	63.8	72.5	76.5	73.8	72.1	71.9	63.8	60.5
	2%	DB	58.5	56.6	58.7	63.1	66.8	74.3	79.3	78.7	76.5	73.3	66.8	61.1
		MCWB	53.7	52.0	54.1	59.4	63.0	70.9	75.5	74.1	71.4	69.3	62.9	58.1
	5%	DB	57.5	56.0	57.6	61.2	65.6	72.8	78.0	77.8	75.7	72.0	65.5	59.5
		MCWB	53.3	51.6	53.2	57.0	62.0	69.0	74.0	73.6	71.0	68.3	62.0	55.8
	10%	DB	56.8	55.4	56.9	60.2	64.6	71.8	76.4	76.7	74.8	71.0	64.3	58.5
		MCWB	52.7	51.3	52.7	55.8	60.9	68.0	72.1	72.8	70.2	67.3	61.0	54.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	55.7	56.6	61.8	65.6	73.5	78.2	76.3	74.5	74.1	65.4	60.8
		MCDB	58.1	56.6	58.8	63.6	67.3	74.8	79.6	78.0	76.3	75.1	66.8	62.8
	2%	WB	55.7	54.7	55.8	60.1	64.2	71.0	76.3	75.4	73.2	70.7	63.9	58.2
		MCDB	57.2	56.1	57.5	62.2	65.9	72.7	78.9	77.5	75.3	72.4	65.7	60.1
	5%	WB	54.8	53.9	55.1	58.5	63.1	69.9	74.8	74.7	72.2	69.6	62.6	56.4
		MCDB	56.6	55.7	56.8	60.6	65.2	71.8	77.7	77.0	74.9	71.7	64.7	58.3
	10%	WB	54.1	53.0	54.5	57.5	62.1	68.8	73.2	73.7	71.2	68.1	61.1	55.3
		MCDB	56.3	55.3	56.4	59.5	64.4	71.0	75.5	76.4	74.4	70.4	64.1	57.4
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	4.1	3.4	3.2	3.3	3.4	3.5	3.7	4.0	3.8	3.5	3.5
		MCDBR	3.8	4.1	3.4	3.8	3.9	3.9	3.7	4.1	4.3	3.6	4.2	3.9
		MCWBR	4.3	4.5	3.4	3.2	3.7	4.2	3.8	4.2	4.9	4.4	5.0	4.8
		MCDBR	3.3	3.6	3.1	3.7	3.7	3.6	3.1	3.6	4.1	3.2	3.8	3.4
	5% WB	MCWBR	4.3	4.7	3.3	3.2	3.9	4.5	3.7	4.4	5.1	4.1	4.9	4.6
(40) Clear-Sky Solar Irradiance	taub		0.332	0.348	0.387	0.410	0.418	0.419	0.419	0.415	0.402	0.391	0.359	0.334
	taud		2.498	2.456	2.358	2.303	2.331	2.367	2.376	2.396	2.414	2.423	2.449	2.487
	Ebn at Noon		258	271	272	273	272	271	268	264	251	243	246	246
	Edh at Noon		23	28	35	40	40	38	37	36	33	29	24	22
(44) All-Sky Solar Radiation	RadAvg		606	895	1337	1760	2093	2381	2336	2049	1545	1035	676	532
	RadStd		55	94	105	107	135	78	84	85	69	82	62	48

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+83

Nomenclature: See separate page