

CORPUS CHRISTI BUOY 42020, USA

WMO: 996190

Lat: 26.968N

Lon: 96.693W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (W06)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.9	10.7	0.7	4.0	13.8	2.8	4.6	14.1	15.5	15.5	14.7	15.2	9.6	350	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	30.1	25.8	29.7	25.9	29.6	25.9	27.9	28.8	27.3	28.7	26.9	28.6	4.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.6	28.6	26.9	22.5	28.5	26.4	21.9	28.3	89.0	28.8	86.1	28.7	84.5	28.6	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.0	11.0	7.3	30.4	2.1	0.6	5.7	30.8	4.5	31.1	3.3	31.5	1.7	31.9
			5.4	27.7	1.6	0.9	4.3	28.3	3.3	28.8	2.4	29.3	1.3	29.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.6	18.1	18.1	19.4	22.1	25.1	27.6	28.3	28.6	27.8	25.8	22.7	19.5
	DBStd	4.47	3.13	3.12	2.40	1.78	1.46	0.79	0.70	0.72	1.16	1.89	2.63	3.21
	HDD10.0	3	1	2	0	0	0	0	0	0	0	0	0	0
	HDD18.3	128	41	36	18	2	0	0	0	0	0	0	5	26
	CDD10.0	4977	253	229	291	362	467	528	569	577	534	491	381	296
	CDD18.3	2061	35	31	50	114	209	278	311	318	284	233	136	63
	CDH23.3	18598	0	0	1	158	1441	3141	3789	4014	3353	2085	570	47
(13)	CDH26.7	5052	0	0	0	0	31	784	1326	1547	1062	299	3	0
(14)	Wind	WSAvg	6.4	7.1	6.8	6.4	6.4	6.1	6.0	5.2	5.5	6.4	7.2	7.3
(15) Precipitation	PrecAvg	882	57	48	55	52	66	82	61	65	166	108	66	56
	PrecMax	1219	178	137	183	164	153	198	256	171	390	326	216	161
	PrecMin	511	8	6	7	2	3	11	9	11	38	6	14	17
	PrecStd	176	35	33	40	43	39	48	60	44	86	73	44	32
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	22.7	23.4	25.7	27.8	29.6	30.0	30.3	30.3	29.4	27.2	24.9
		MCWB	20.9	21.2	21.6	22.9	25.5	25.5	25.6	25.8	25.7	26.5	24.8	22.6
	2%	DB	22.7	22.3	22.8	25.2	27.4	29.1	29.6	30.1	29.9	28.9	26.5	24.4
		MCWB	20.6	20.8	21.2	23.3	25.4	25.6	25.6	25.8	25.8	25.7	23.7	22.1
	5%	DB	22.3	21.9	22.4	24.8	27.0	28.9	29.5	29.9	29.6	28.5	26.1	24.0
		MCWB	20.3	20.5	20.9	23.1	25.1	25.6	25.6	25.9	25.8	25.2	23.1	21.8
	10%	DB	21.9	21.5	21.9	24.4	26.8	28.6	29.2	29.7	29.4	28.2	25.7	23.5
		MCWB	19.9	20.1	20.6	22.8	24.8	25.6	25.7	26.0	25.6	24.8	22.6	21.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	21.8	22.5	24.9	27.3	28.0	28.6	28.5	28.0	27.7	26.5	24.1
		MCDB	22.5	22.0	22.9	25.1	27.4	28.6	28.6	29.0	29.4	28.6	26.6	24.2
	2%	WB	21.5	21.4	22.0	24.1	26.7	27.3	27.9	27.6	26.9	26.8	24.7	23.2
		MCDB	22.2	21.7	22.4	24.6	26.9	28.5	28.6	29.2	29.1	28.3	25.9	23.5
	5%	WB	20.9	21.0	21.6	23.8	26.1	26.8	27.2	27.0	26.6	26.3	24.0	22.6
		MCDB	21.9	21.4	22.2	24.3	26.5	28.4	28.5	29.1	29.0	28.1	25.3	23.2
	10%	WB	20.3	20.6	21.2	23.4	25.5	26.4	26.8	26.7	26.2	25.6	23.3	22.0
		MCDB	21.5	21.2	21.8	24.0	26.2	28.2	28.5	29.0	28.8	27.8	25.2	23.0
(35) Mean Daily Temperature Range	5% DB	MDBR	3.3	2.9	2.2	1.5	1.1	1.1	1.1	1.3	1.8	1.8	2.5	3.3
		MCDBR	2.8	2.3	1.8	1.3	1.3	1.4	1.1	1.4	1.6	1.7	2.3	2.9
		MCWBR	3.5	3.0	2.0	1.8	1.6	1.6	1.3	1.4	1.8	2.2	3.1	4.2
	5% WB	MCDBR	2.9	2.3	1.6	1.5	1.4	1.2	1.1	1.2	1.7	1.7	2.6	3.2
		MCWBR	3.9	3.0	2.0	1.8	1.7	1.7	1.7	1.6	2.1	2.5	3.7	4.0
(40) Clear-Sky Solar Irradiance	taub		0.376	0.387	0.397	0.452	0.484	0.453	0.471	0.454	0.443	0.401	0.384	0.373
	taud		2.479	2.447	2.420	2.258	2.199	2.364	2.321	2.377	2.363	2.483	2.490	2.499
	Ebn at Noon		869	888	897	852	821	841	825	839	841	862	854	856
	Edh at Noon		96	107	115	139	148	124	130	122	120	102	94	91
(44) All-Sky Solar Radiation	RadAvg		2.99	3.66	4.70	5.64	6.41	6.86	6.72	6.43	5.31	4.66	3.48	2.70
	RadStd		0.35	0.57	0.49	0.55	0.39	0.31	0.49	0.30	0.41	0.42	0.36	0.37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+105

Nomenclature: See separate page