

NORTH NOMAD BUOY 46184, Canada

WMO: 996210

Lat: 53.910N

Lon: 138.850W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-0.6	0.8	N/A	N/A	N/A	N/A	N/A	N/A	18.4	3.1	17.5	3.3	9.8	10	0.900

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.1	15.8	N/A	15.4	N/A	14.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
16.8	15.4	14.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	5.2	4.8	3.9	5.2	7.1	9.5	11.8	13.4	12.8	10.4	7.5	5.9
	DBStd	3.58	2.01	1.62	1.66	1.07	1.37	1.47	1.35	1.21	1.23	1.55	2.25	1.84
	HDD10.0	966	148	147	191	144	89	26	1	0	0	14	78	128
	HDD18.3	3720	407	380	449	394	347	264	203	152	167	246	325	386
	CDD10.0	287	0	0	0	0	0	12	56	107	83	27	3	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	7.7	9.2	9.0	7.9	7.3	6.6	5.9	5.9	6.3	7.7	8.5	9.4	9.2
Precipitation	PrecAvg	1293	151	116	97	70	61	62	73	85	127	156	136	158
	PrecMax	1473	253	216	161	119	96	94	129	136	207	214	192	246
	PrecMin	1104	76	48	54	25	29	35	26	28	72	65	71	100
	PrecStd	106	42	38	32	21	17	17	23	24	33	30	39	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	8.7	7.2	7.7	10.7	14.6	15.0	16.4	16.3	14.2	12.7	10.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	8.7	8.1	6.7	7.4	10.2	13.1	14.5	16.0	15.7	13.6	11.9	9.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	8.2	7.5	6.3	7.1	9.7	12.2	14.1	15.6	15.2	13.1	11.0	8.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	7.7	7.0	5.9	6.7	9.0	11.5	13.7	15.2	14.6	12.6	10.3	8.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.0	1.8	2.0	1.5	1.2	1.2	1.1	1.1	1.4	1.6	2.1	2.1
		MCDBR	1.6	1.7	1.8	1.4	1.3	1.5	1.3	1.2	1.5	1.6	1.8	2.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.324	0.332	0.355	0.399	0.403	0.375	0.383	0.388	0.387	0.364	0.330	0.311
	taud		2.317	2.411	2.354	2.222	2.273	2.442	2.470	2.447	2.366	2.320	2.277	2.273
	Ebn at Noon		626	766	822	825	844	874	860	833	778	703	600	555
	Edh at Noon		59	74	96	124	124	106	102	99	95	79	60	50
All-Sky Solar Radiation	RadAvg		0.56	1.26	2.53	3.87	4.57	4.82	4.08	3.63	2.84	1.59	0.77	0.44
	RadStd		0.05	0.14	0.14	0.22	0.33	0.36	0.36	0.31	0.22	0.15	0.06	0.04

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page