

SANTA BARBARA BUOY 46053, CA, USA

WMO: 996400

Lat: 34.252N

Lon: 119.853W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (NAP)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	49.6	50.7	N/A	N/A	N/A	N/A	N/A	N/A	32.9	55.3	31.5	55.4	14.0	300	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.8	71.1	N/A	69.4	N/A	68.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
29.6	25.0	22.6	47.2	72.2	2.3	2.2	45.6	73.8	44.2	75.2	42.9	76.4	41.2	78.0		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.7	57.1	55.9	55.2	55.2	56.6	59.0	60.9	61.7	62.6	62.4	60.3	57.0
	DBStd	3.79	2.78	2.42	2.40	1.89	2.13	2.23	2.66	2.86	3.52	3.41	2.77	2.49
	HDD50	1	0	0	1	0	0	0	0	0	0	0	0	0
	HDD65	2358	245	256	302	293	262	180	130	110	91	99	143	247
	CDD50	3165	220	165	163	157	203	270	339	362	377	383	308	218
	CDD65	48	0	0	0	0	0	1	4	7	18	17	1	0
	CDH74	3	0	0	0	0	0	0	0	0	1	2	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.1	8.4	10.6	10.8	12.0	11.4	9.9	10.3	10.3	9.9	9.0	8.8	9.4
Precipitation	PrecAvg	23.2	6.6	4.8	3.8	1.4	0.6	0.1	0.0	0.0	0.0	0.9	1.4	3.9
	PrecMax	33.9	25.0	12.0	14.6	6.5	3.1	0.5	0.2	0.1	0.3	5.7	5.2	10.9
	PrecMin	9.4	0.8	0.4	0.0	0.4	0.1	0.0	0.0	0.0	0.0	0.0	0.3	0.5
	PrecStd	7.8	6.5	3.0	4.2	1.5	0.8	0.1	0.0	0.0	0.1	1.4	1.4	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.6	63.3	63.5	63.0	64.2	67.8	70.3	71.3	73.2	73.4	68.6	65.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	63.4	61.1	60.9	60.2	61.9	64.5	68.0	68.7	71.4	70.6	66.6	63.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	61.8	59.9	59.5	58.7	60.4	63.0	66.3	67.1	69.6	69.1	65.3	61.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	60.4	59.0	58.4	57.5	59.4	62.0	64.8	65.8	67.7	67.6	64.2	60.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.2	4.3	4.1	4.1	4.0	3.7	3.6	3.8	4.1	4.1	3.9
		MCDBR	6.3	5.4	5.9	5.6	5.6	5.6	4.4	4.3	4.4	5.5	5.6	4.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.303	0.317	0.328	0.363	0.376	0.363	0.393	0.372	0.359	0.350	0.309	0.311	
	taud	2.606	2.582	2.550	2.434	2.415	2.453	2.423	2.450	2.498	2.515	2.607	2.594	
	Ebn at Noon	291	298	301	293	288	291	281	286	286	281	286	280	
	Edh at Noon	24	28	31	36	37	36	37	35	32	29	24	23	
All-Sky Solar Radiation	RadAvg	979	1254	1681	2089	2272	2320	2241	2106	1826	1412	1098	887	
	RadStd	73	125	110	122	168	115	103	96	90	115	65	72	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+1.12	N/A	-2.95	+1.28	N/A	N/A	N/A	-232	+405	+158

Nomenclature: See separate page