

C DIXON ENTRANCE BUOY 46145, CanadaWMO: **996410**Lat: **54.370N**Lon: **132.440W**Elev: **10**StdP: **14.69**Time Zone: **-9.00 (W09)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	25.6	29.2	N/A	N/A	N/A	N/A	N/A	N/A	39.5	40.1	36.5	40.4	16.7	70	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	59.5	N/A	58.5	N/A	57.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
35.9	31.9	28.2	DB	23.4	60.5	4.4	1.8	20.2	61.8	17.7	62.8	15.2	63.8	12.0	65.1
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	41.0	41.2	40.7	43.7	47.1	51.0	54.2	55.7	54.1	50.0	44.4	41.9
	DBStd	6.35	5.30	3.87	3.93	2.40	2.33	2.19	1.92	1.79	1.84	2.62	4.19	4.44
	HDD50	1558	281	246	288	190	92	11	0	0	0	31	168	251
	HDD65	6529	745	666	753	639	554	420	336	288	328	466	618	716
	CDD50	504	1	0	0	0	3	42	129	177	122	30	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.3	16.3	15.7	14.7	12.6	12.0	11.3	10.9	10.1	10.8	14.0	15.8	16.1
Precipitation	PrecAvg	100.0	11.6	8.6	8.4	6.7	4.6	3.8	3.7	5.5	8.0	13.0	13.0	13.0
	PrecMax	130.1	18.6	15.0	13.4	11.0	11.0	6.9	7.4	11.1	16.9	20.0	24.9	29.2
	PrecMin	72.4	5.8	3.8	3.5	3.6	1.1	2.1	1.4	2.2	3.5	5.7	7.5	6.8
	PrecStd	14.2	2.8	2.9	2.7	1.8	2.2	1.1	1.4	2.3	2.9	3.5	3.3	4.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	49.4	48.6	51.7	54.4	60.6	59.8	61.6	59.3	56.1	51.9	50.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.1	48.1	47.2	49.0	52.0	56.5	58.4	60.1	58.2	54.7	50.6	49.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	47.6	47.1	46.2	47.6	51.0	54.9	57.5	59.1	57.5	53.9	49.9	48.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	46.4	45.9	45.1	46.6	50.2	53.8	56.8	58.3	56.7	53.1	49.1	46.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.8	3.7	3.9	3.3	2.8	2.6	2.3	2.6	2.8	3.2	3.9	3.9
		MCDBR	4.0	3.5	3.7	3.9	3.6	3.7	3.0	3.4	3.3	3.6	3.9	4.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.311	0.320	0.344	0.378	0.375	0.372	0.374	0.370	0.365	0.345	0.317	0.304	
	taud	2.374	2.477	2.427	2.328	2.401	2.451	2.487	2.515	2.481	2.430	2.342	2.299	
	Ebn at Noon	204	248	265	269	276	278	275	270	255	232	196	176	
	Edh at Noon	17	22	28	35	35	33	32	29	27	23	17	15	
All-Sky Solar Radiation	RadAvg	158	410	753	1211	1485	1579	1406	1229	850	466	219	126	
	RadStd	19	67	90	61	110	122	131	112	86	51	24	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page