

C DIXON ENTRANCE BUOY 46145, Canada

WMO: 996410

Lat: 54.370N

Lon: 132.440W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-3.6	-1.6	N/A	N/A	N/A	N/A	N/A	N/A	17.6	4.5	16.3	4.7	7.5	70	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.5	15.3	N/A	14.7	N/A	14.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
16.1	14.3	12.6	DB	-4.8	15.8	2.4	1.0	-6.5	16.5	-8.0	17.1	-9.3	17.7	-11.1	18.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	5.0	5.1	4.8	6.5	8.4	10.6	12.3	13.2	12.3	10.0	6.9	5.5
	DBStd	3.53	2.95	2.15	2.19	1.33	1.29	1.22	1.07	1.00	1.02	1.45	2.33	2.47
	HDD10.0	866	156	137	160	106	51	6	0	0	0	17	93	139
	HDD18.3	3627	414	370	418	355	308	233	187	160	182	259	343	398
	CDD10.0	280	1	0	0	0	2	23	72	98	68	17	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.0	7.3	7.0	6.6	5.7	5.3	5.1	4.9	4.5	4.8	6.2	7.1	7.2
Precipitation	PrecAvg	2539	294	219	214	171	116	97	94	139	204	330	330	331
	PrecMax	3305	472	381	340	280	280	175	189	282	428	509	632	741
	PrecMin	1838	148	96	88	92	29	53	36	55	88	146	191	173
	PrecStd	360	70	73	68	46	57	29	36	59	74	90	84	114
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	9.6	9.2	11.0	12.4	15.9	15.4	16.5	15.2	13.4	11.1	10.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.5	8.9	8.4	9.5	11.1	13.6	14.7	15.6	14.6	12.6	10.3	9.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	8.7	8.4	7.9	8.6	10.5	12.7	14.2	15.1	14.1	12.2	9.9	8.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.0	7.7	7.3	8.1	10.1	12.1	13.8	14.6	13.7	11.7	9.5	8.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.1	2.0	2.2	1.8	1.5	1.4	1.3	1.5	1.5	1.8	2.2	2.2
		MCDBR	2.2	2.0	2.0	2.2	2.0	2.0	1.7	1.9	1.8	2.0	2.2	2.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.311	0.320	0.344	0.378	0.375	0.372	0.374	0.370	0.365	0.345	0.317	0.304	
	taud	2.374	2.477	2.427	2.328	2.401	2.451	2.487	2.515	2.481	2.430	2.342	2.299	
	Ebn at Noon	643	782	836	848	871	877	867	851	805	730	619	556	
	Edh at Noon	55	68	89	111	109	105	100	92	84	71	55	48	
All-Sky Solar Radiation	RadAvg	0.50	1.29	2.37	3.82	4.68	4.98	4.43	3.87	2.68	1.47	0.69	0.40	
	RadStd	0.06	0.21	0.28	0.19	0.35	0.39	0.41	0.35	0.27	0.16	0.08	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page