

LONG ISLAND BUOY 44025, USA

WMO: 996420

Lat: 40.251N

Lon: 73.164W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.7	(c) -5.3	(d) -15.3	(e) 1.0	(f) -5.7	(g) -13.3	(h) 1.2	(i) -4.6	(j) 17.4	(k) -2.6	(l) 16.4	(m) -0.6	(n) 8.3	(o) 290	(p) 0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.1	25.8	23.7	25.4	23.4	24.7	22.8	24.8	25.4	24.1	24.9	23.5	24.4	4.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	19.4	25.2	23.8	18.6	24.7	23.1	17.9	24.1	75.2	25.5	72.3	25.0	69.9	24.4	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.5	(b) 14.0	(c) 11.8	(e) -9.2	(f) 26.4	(g) 2.8	(h) 1.0	(i) -11.2	(j) 27.2	(k) -12.8	(l) 27.7	(m) -14.4	(n) 28.3	(o) -16.5	(p) 29.0		
(4) 15.5	(5) 14.0	(6) 11.8	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	2.6	2.7	4.7	8.2	12.6	18.3	22.5	22.4	20.0	14.9	10.3	6.2		
	DBStd	7.70	4.62	3.44	2.70	2.27	2.43	2.65	1.71	1.72	2.09	2.70	3.42	4.04		
	HDD10.0	828	229	203	165	60	3	0	0	0	0	2	37	128		
	HDD18.3	2594	487	437	423	303	177	33	0	0	9	108	241	376		
	CDD10.0	1624	1	0	0	8	85	248	387	386	299	155	46	10		
	CDD18.3	348	0	0	0	0	1	31	128	127	58	3	0	0		
	CDH23.3	585	0	0	0	0	0	7	282	268	28	0	0	0		
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0		
(14) Wind	WSAvg	5.5	6.8	6.6	6.0	5.0	4.4	4.4	4.2	4.0	4.8	6.0	6.5	7.1		
(15) Precipitation	PrecAvg	1164	88	76	106	99	96	100	94	115	97	99	86	109		
	PrecMax	1459	207	148	224	222	202	229	166	341	228	386	147	189		
	PrecMin	926	40	26	27	40	33	22	25	18	35	8	33	34		
	PrecStd	146	34	32	45	44	35	51	38	63	48	74	32	35		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	10.3	11.2	14.7	20.2	24.3	26.8	26.4	25.1	21.4	17.3	15.1		
		MCWB	11.6	9.4	10.2	12.4	18.5	21.9	24.3	24.0	23.8	20.0	16.1	14.1		
	2%	DB	11.0	9.0	10.0	12.9	18.4	23.3	26.1	25.8	24.2	20.3	16.4	13.9		
		MCWB	10.0	7.9	8.9	11.0	17.2	21.5	23.9	23.7	22.5	18.9	15.0	12.8		
	5%	DB	9.9	8.0	9.0	11.8	16.9	22.6	25.5	25.4	23.4	19.4	15.6	13.0		
		MCWB	8.7	6.7	7.8	9.9	16.0	21.0	23.5	23.5	21.6	17.5	14.3	11.9		
	10%	DB	8.8	7.0	8.0	10.9	15.7	21.7	24.9	24.8	22.8	18.6	15.0	12.0		
		MCWB	7.2	5.5	6.8	9.2	14.7	20.2	23.0	22.9	20.9	16.5	13.6	10.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	10.0	10.8	13.5	19.3	23.1	25.4	25.4	24.6	20.8	16.5	14.7		
		MCDB	12.3	10.4	10.9	14.3	19.6	23.6	26.1	25.8	24.9	21.2	16.9	14.9		
	2%	WB	10.8	8.5	9.5	11.9	17.8	22.3	24.8	24.8	23.1	19.8	15.4	13.2		
		MCDB	11.2	9.0	10.1	12.7	18.4	23.0	25.6	25.4	23.7	20.5	15.7	13.6		
	5%	WB	9.3	7.2	8.4	10.8	16.5	21.5	24.1	24.1	22.4	18.4	14.8	12.1		
		MCDB	9.9	7.9	8.9	11.5	17.1	22.2	25.0	24.9	23.1	19.1	15.2	12.8		
	10%	WB	7.8	5.8	7.3	9.9	15.3	20.7	23.5	23.7	21.6	17.4	13.9	11.0		
		MCDB	8.7	6.8	8.0	10.7	15.9	21.4	24.4	24.5	22.4	18.4	14.6	11.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.5	4.1	3.4	2.8	2.4	2.2	2.1	2.1	2.2	3.0	3.4	4.2		
		MCDBR	4.9	4.6	3.8	3.6	3.2	2.6	2.3	2.3	2.3	3.0	3.2	4.7		
	5% WB	MCWBR	5.8	5.8	4.0	3.2	2.9	2.7	2.8	2.8	2.9	4.4	4.1	6.5		
		MCWBR	4.9	4.7	3.8	3.4	2.8	2.4	2.3	1.9	2.2	2.7	3.3	4.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.328	0.339	0.362	0.383	0.432	0.472	0.484	0.467	0.400	0.370	0.339	0.329		
		taud	2.474	2.441	2.415	2.385	2.283	2.214	2.186	2.234	2.389	2.470	2.510	2.508		
	Ebn at Noon	Ebn at Noon	833	876	891	891	850	814	799	803	840	829	814	803		
		Edh at Noon	78	93	106	116	132	141	144	134	108	89	75	71		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.85	2.76	3.86	4.96	5.55	6.09	6.13	5.52	4.48	3.12	2.14	1.61		
	RadStd	RadStd	0.17	0.28	0.33	0.47	0.56	0.58	0.31	0.37	0.37	0.28	0.19	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (55 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	+67

Nomenclature: See separate page