

SANDETTIE LIGHT BUOY 6230, France

WMO: 996480

Lat: 51.102N

Lon: 1.800E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 01-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.3	0.8	-5.8	2.3	1.0	-4.2	2.6	1.5	23.9	8.7	22.0	9.0	8.8	60	0.880

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	20.5	17.7	19.3	17.2	18.7	16.9	18.4	19.6	17.9	18.9	17.4	18.4	5.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	12.9	19.0	17.4	12.5	18.6	16.9	12.0	18.2	52.1	19.6	50.4	19.0	48.9	18.4	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.4	16.3	DB	-2.5	25.0	3.0	2.2	-4.7	26.6	-6.5	27.9	-8.2	29.2	-10.4	30.8	(4)
(5)			WB	-3.7	20.0	3.0	0.9	-5.8	20.7	-7.6	21.2	-9.2	21.8	-11.4	22.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	6.5	5.9	7.0	9.0	11.4	14.0	16.3	17.3	16.2	13.4	10.4	7.5
	DBStd	4.50	2.90	2.63	2.23	2.04	1.74	1.62	1.51	1.37	1.51	2.26	2.39	2.99
	HDD10.0	481	112	115	96	41	6	0	0	0	0	4	22	86
	HDD18.3	2586	368	347	352	279	214	129	65	39	67	152	237	335
	CDD10.0	949	2	1	2	13	50	121	197	225	184	110	35	9
	CDD18.3	11	0	0	0	0	0	1	3	6	1	0	0	0
	CDH23.3	7	0	0	0	0	0	1	2	4	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	8.6	10.2	9.4	8.4	7.3	7.7	7.3	7.5	7.4	8.0	9.1	10.1	10.4
Precipitation	PrecAvg	657	60	47	38	42	47	50	48	56	53	75	77	65
	PrecMax	897	130	103	98	117	110	114	82	116	103	189	143	115
	PrecMin	495	16	8	7	4	7	12	12	10	6	8	28	14
	PrecStd	99	27	27	21	27	26	30	21	32	27	39	33	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	11.9	12.9	15.2	17.2	20.6	21.5	23.3	20.7	18.7	16.1	14.1
		MCWB	11.0	9.5	9.6	11.7	13.3	16.8	18.4	19.1	17.4	16.5	14.4	11.9
	2%	DB	11.6	10.9	10.9	13.5	15.1	17.6	19.7	21.0	19.4	17.7	15.1	13.0
		MCWB	10.3	9.4	8.8	10.7	12.7	15.4	17.5	18.2	17.1	16.0	13.4	11.4
	5%	DB	10.9	10.1	10.2	12.3	14.2	16.5	18.8	19.5	18.7	17.1	14.5	12.3
		MCWB	9.6	8.7	8.5	10.2	12.4	14.7	16.9	17.5	16.8	15.5	12.8	10.7
	10%	DB	10.2	9.3	9.6	11.4	13.5	15.7	18.1	18.8	18.1	16.4	13.8	11.6
		MCWB	8.9	7.9	8.2	9.8	12.0	14.2	16.6	17.1	16.5	14.8	12.1	10.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	10.2	10.2	12.3	14.4	17.5	18.8	20.0	18.3	17.2	14.9	12.5
		MCDB	12.0	11.2	11.6	14.1	15.9	19.5	20.3	22.8	19.1	18.1	16.0	13.3
	2%	WB	10.7	9.7	9.5	11.3	13.2	15.8	18.1	18.7	17.8	16.4	13.9	11.8
		MCDB	11.4	10.7	10.5	12.7	14.3	17.1	19.1	20.0	18.7	17.5	14.9	12.8
	5%	WB	9.8	8.9	8.9	10.7	12.7	15.1	17.5	18.1	17.4	15.9	13.1	11.1
		MCDB	10.7	9.8	9.8	11.9	13.8	16.1	18.5	19.2	18.4	17.0	14.3	12.3
	10%	WB	9.1	8.2	8.4	10.1	12.3	14.6	16.8	17.5	16.9	15.2	12.2	10.2
		MCDB	10.1	9.2	9.4	11.2	13.4	15.6	17.9	18.5	18.0	16.3	13.6	11.4
Mean Daily Temperature Range	5% DB	MDBR	2.9	2.7	2.6	2.4	2.2	2.1	2.2	2.4	2.4	2.9	2.9	3.1
		MCDBR	3.0	3.0	3.4	4.1	3.4	3.7	3.3	3.5	3.0	3.3	3.3	3.2
		MCWBR	3.6	2.9	2.9	2.6	2.4	2.9	2.2	2.5	2.7	3.3	3.7	3.7
	5% WB	MCDBR	2.9	2.9	3.0	3.7	3.0	3.2	3.1	3.3	2.7	3.3	3.4	3.1
		MCWBR	3.6	2.9	2.9	2.6	2.4	2.8	2.3	2.6	2.6	3.5	3.8	3.8
Clear-Sky Solar Irradiance	taub	0.336	0.354	0.392	0.408	0.417	0.416	0.414	0.406	0.386	0.371	0.345	0.328	
	taud	2.376	2.368	2.265	2.256	2.289	2.310	2.324	2.366	2.411	2.418	2.401	2.364	
	Ebn at Noon	675	766	798	830	840	842	836	824	800	736	658	618	
	Edh at Noon	64	83	109	123	125	123	120	109	94	78	62	56	
All-Sky Solar Radiation	RadAvg	0.80	1.49	2.67	4.32	5.10	5.62	5.36	4.50	3.35	1.91	0.94	0.61	
	RadStd	0.07	0.23	0.33	0.39	0.37	0.45	0.47	0.34	0.23	0.17	0.10	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page