

W DIXON ENTRANCE BUOY 46205, Canada

WMO: 996490

Lat: 54.160N

Lon: 134.280W

Elev: 10

StdP: 14.69

Time Zone: -9.00 (W09)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	28.3	32.1	N/A	N/A	N/A	N/A	N/A	N/A	43.4	42.1	40.6	42.0	19.8	30	0.858

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.3	61.7	N/A	60.6	N/A	59.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
38.6	34.8	31.7	27.5	60.7	3.6	2.4	24.9	62.5	22.8	63.9	20.8	65.3	18.2	67.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	42.6	41.9	41.4	43.4	46.6	50.9	55.0	57.3	55.8	51.4	45.7	43.4
	DBStd	6.40	4.39	3.67	3.96	2.17	2.46	2.46	2.29	2.25	2.13	2.45	4.04	3.88
	HDD50	1400	229	226	266	199	109	17	0	0	0	15	134	205
	HDD65	6215	694	646	731	649	572	424	311	240	276	423	580	669
	CDD50	660	0	0	0	0	3	43	154	225	174	57	4	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.7	21.0	18.7	18.5	16.3	14.2	12.5	12.4	12.8	15.5	18.3	20.3	20.2
Precipitation	PrecAvg	70.4	8.2	5.9	5.7	4.4	3.2	3.0	3.2	4.2	5.7	8.6	9.1	9.1
	PrecMax	88.6	11.4	9.6	8.8	8.1	7.0	4.4	5.7	7.0	9.9	13.3	15.5	16.3
	PrecMin	56.5	4.9	1.9	2.8	2.6	0.2	1.9	1.0	2.1	2.5	3.6	5.9	5.4
	PrecStd	7.8	1.6	2.0	1.5	1.1	1.4	0.8	1.2	1.5	1.7	2.2	2.0	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.1	50.0	49.3	50.4	53.2	58.5	60.2	64.0	61.8	58.4	53.8	51.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.0	48.4	47.9	48.0	51.7	56.7	59.4	62.8	60.8	56.5	52.6	50.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	48.1	46.8	46.7	47.0	50.9	55.6	58.9	61.5	59.9	55.6	51.6	48.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	47.2	46.2	45.9	46.3	50.1	54.4	58.2	60.5	59.0	54.8	50.6	47.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.9	3.6	4.0	3.1	2.4	2.2	2.2	2.3	2.7	3.1	4.0	3.8
		MCDBR	3.4	3.3	4.0	3.5	2.7	2.9	2.6	2.6	3.1	3.5	3.6	3.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.316	0.322	0.347	0.393	0.387	0.377	0.376	0.380	0.384	0.354	0.321	0.309	
	taud	2.352	2.472	2.410	2.258	2.349	2.437	2.495	2.480	2.390	2.381	2.326	2.283	
	Ebn at Noon	202	248	264	264	272	277	275	266	248	227	195	175	
	Edh at Noon	18	22	29	38	36	34	31	30	29	23	18	16	
All-Sky Solar Radiation	RadAvg	165	414	787	1244	1476	1586	1371	1218	883	493	233	129	
	RadStd	17	61	74	65	95	120	95	111	83	47	23	17	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page