

WEST MORESBY BUOY 46208, CanadaWMO: **996510**Lat: **52.520N**Lon: **132.690W**Elev: **10**StdP: **14.69**Time Zone: **-9.00 (W09)**Period: **01-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	30.8	34.2	N/A	N/A	N/A	N/A	N/A	N/A	43.5	43.1	39.8	43.3	19.2	10	0.845

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	62.1	N/A	61.1	N/A	60.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
38.3	34.4	31.2	28.1	61.8	5.9	1.9	23.8	63.2	20.3	64.4	17.0	65.5	12.7	66.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	43.5	43.2	42.3	44.0	47.2	51.4	55.3	57.8	56.5	52.2	46.7	44.2
	DBStd	6.19	3.88	3.29	3.65	2.25	2.22	2.41	2.31	2.29	1.91	2.73	3.81	3.77
	HDD50	1210	201	191	240	181	89	11	0	0	0	12	105	180
	HDD65	5939	666	611	705	630	551	407	299	224	256	398	548	644
	CDD50	744	0	0	0	0	3	53	166	241	194	78	8	1
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	16.5	19.4	17.6	18.1	16.3	14.7	13.5	13.3	12.6	14.8	17.8	19.6	20.2
	PrecAvg	70.4	8.2	5.9	5.7	4.4	3.2	3.0	3.2	4.2	5.7	8.6	9.1	9.1
Precipitation	PrecMax	88.6	11.4	9.6	8.8	8.1	7.0	4.4	5.7	7.0	9.9	13.3	15.5	16.3
	PrecMin	56.5	4.9	1.9	2.8	2.6	0.2	1.9	1.0	2.1	2.5	3.6	5.9	5.4
	PrecStd	7.8	1.6	2.0	1.5	1.1	1.4	0.8	1.2	1.5	1.7	2.2	2.0	2.6
	PrecStd	7.8	1.6	2.0	1.5	1.1	1.4	0.8	1.2	1.5	1.7	2.2	2.0	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	50.4	50.4	51.8	53.0	59.7	61.0	64.6	62.0	59.0	54.6	52.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.8	49.2	49.2	49.1	51.9	57.4	60.1	63.3	60.8	57.6	53.4	51.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	48.6	48.2	48.1	47.9	51.1	56.2	59.3	62.0	60.1	56.8	52.4	49.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	47.8	47.2	47.0	47.0	50.4	54.7	58.7	61.1	59.3	55.7	51.4	48.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.3	3.8	3.1	2.4	2.3	2.2	2.4	2.7	3.2	4.0	3.8
		MCDBR	3.3	3.5	3.5	4.0	2.7	3.2	2.6	2.9	2.9	3.5	3.9	3.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.323	0.328	0.355	0.394	0.394	0.377	0.378	0.383	0.377	0.356	0.329	0.315
	taud		2.368	2.462	2.386	2.268	2.330	2.442	2.487	2.477	2.441	2.402	2.336	2.320
	Ebn at Noon		211	251	264	266	272	278	276	268	254	234	203	189
	Edh at Noon		19	23	30	38	38	34	32	31	29	24	19	17
All-Sky Solar Radiation	RadAvg		194	459	816	1278	1528	1605	1444	1276	960	537	263	161
	RadStd		22	71	81	69	93	117	122	100	81	52	25	21

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page