

TANNER BANKS BUOY 46047, USA

WMO: 996740

Lat: 32.404N

Lon: 119.506W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	51.5	52.4	N/A	N/A	N/A	N/A	N/A	N/A	34.5	55.1	32.9	55.0	16.7	310	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.3	69.9	N/A	68.6	N/A	67.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
31.2	26.9	24.8	50.1	71.1	2.7	2.2	48.2	72.7	46.6	74.0	45.1	75.2	43.2	76.8		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.1	57.2	56.3	56.3	56.1	56.8	58.1	60.6	62.5	63.6	63.1	60.9	58.0
	DBStd	3.57	2.51	2.20	2.30	1.87	1.88	1.83	2.41	2.35	2.81	2.83	2.20	2.38
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	2187	241	243	270	266	255	208	139	86	61	75	124	219
	CDD50	3335	224	177	195	184	210	242	330	386	407	406	327	247
	CDD65	46	0	0	0	0	0	0	4	7	18	16	1	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.2	12.5	13.7	14.8	16.0	16.9	15.7	13.3	14.5	13.9	13.1	12.6	13.2
Precipitation	PrecAvg	3.8	0.5	0.6	0.4	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.6
	PrecMax	7.2	1.6	1.9	1.6	0.8	0.7	0.8	1.1	0.8	1.1	1.2	1.1	1.3
	PrecMin	2.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	PrecStd	1.2	0.4	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.3	64.9	64.8	61.5	62.1	64.5	68.5	69.2	72.4	71.4	67.1	65.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	63.0	62.0	62.0	60.4	60.9	62.3	67.1	68.0	70.5	69.9	66.0	64.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	62.0	60.4	60.5	59.6	60.3	61.4	65.9	67.0	68.9	68.4	65.1	62.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	60.7	59.5	59.5	58.9	59.7	60.8	64.4	66.1	67.7	67.3	64.2	61.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.9	2.8	2.7	2.4	2.0	2.2	2.2	2.0	2.3	2.6	2.5	2.5
		MCDBR	3.7	3.6	3.2	3.0	2.5	2.5	2.6	2.1	3.2	3.4	3.1	2.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.306	0.318	0.329	0.348	0.354	0.352	0.367	0.355	0.346	0.346	0.313	0.307
	taud		2.625	2.601	2.559	2.487	2.486	2.499	2.515	2.520	2.550	2.545	2.618	2.627
	Ebn at Noon		294	299	302	298	295	294	289	292	292	285	288	287
	Edh at Noon		24	28	31	35	35	34	34	33	31	29	24	23
All-Sky Solar Radiation	RadAvg		1043	1289	1630	1965	1878	1686	1598	1555	1566	1308	1112	950
	RadStd		52	102	122	144	243	143	150	184	161	166	96	79

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.88	N/A	-2.88	+1.15	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page