

TANNER BANKS BUOY 46047, USA

WMO: 996740

Lat: 32.404N

Lon: 119.506W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (W08)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.9	11.3	N/A	N/A	N/A	N/A	N/A	N/A	15.4	12.8	14.7	12.8	7.5	310	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.3	21.0	N/A	20.3	N/A	19.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.0	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	12.0	11.1	DB	10.1	21.7	1.5	1.2	9.0	22.6	8.1	23.3	7.3	24.0	6.2	24.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.1	14.0	13.5	13.5	13.4	13.8	14.5	15.9	16.9	17.5	17.3	16.1	14.4	(6)	
(7)		DBStd	1.98	1.40	1.22	1.28	1.04	1.05	1.02	1.34	1.31	1.56	1.57	1.22	1.32	(7)	
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
(9)		HDD18.3	1215	134	135	150	148	142	116	77	48	34	42	69	122	(9)	
(10)		CDD10.0	1853	124	98	108	102	117	134	183	214	226	226	182	137	(10)	
(11)		CDD18.3	26	0	0	0	0	0	0	2	4	10	9	1	0	(11)	
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	6.3	5.6	6.1	6.6	7.2	7.6	7.0	6.0	6.5	6.2	5.9	5.6	5.9	(14)	
(15)	Precipitation	PrecAvg	97	13	15	10	5	6	5	4	4	7	7	8	14	(15)	
(16)		PrecMax	183	41	47	41	21	17	20	29	21	29	31	29	33	(16)	
(17)		PrecMin	50	1	2	1	1	0	1	0	0	0	1	2	1	(17)	
(18)		PrecStd	30	10	12	8	5	5	4	5	4	6	6	6	10	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	18.3	18.2	16.4	16.7	18.0	20.3	20.7	22.5	21.9	19.5	18.8	(19)	
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	17.2	16.7	16.7	15.8	16.1	16.9	19.5	20.0	21.4	21.0	18.9	17.9	(21)	
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	16.6	15.8	15.8	15.3	15.7	16.4	18.9	19.4	20.5	20.2	18.4	17.0	(23)	
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)		10%	DB	15.9	15.3	15.3	15.0	15.4	16.0	18.0	18.9	19.9	19.6	17.9	16.3	(25)	
(26)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
(28)			MCD B	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)
(30)			MCD B	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)
(32)			MCD B	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)		10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)
(34)			MCD B	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	1.6	1.5	1.5	1.3	1.1	1.2	1.2	1.1	1.3	1.5	1.4	1.4	(35)	
(36)			MCDBR	2.1	2.0	1.8	1.7	1.4	1.4	1.4	1.2	1.8	1.9	1.7	1.5	(36)	
(37)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)
(38)		5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)
(39)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.318	0.329	0.348	0.354	0.352	0.367	0.355	0.346	0.346	0.313	0.307	(40)		
(41)		taud	2.625	2.601	2.559	2.487	2.486	2.499	2.515	2.520	2.550	2.545	2.618	2.627	(41)		
(42)		Ebn at Noon	926	944	953	941	931	928	912	922	922	899	909	905	(42)		
(43)		Edh at Noon	77	87	97	109	110	108	106	104	97	90	77	73	(43)		
(44)	All-Sky Solar Radiation	RadAvg	3.29	4.06	5.14	6.19	5.92	5.32	5.04	4.90	4.94	4.12	3.50	2.99	(44)		
(45)		RadStd	0.16	0.32	0.39	0.45	0.77	0.45	0.47	0.58	0.51	0.52	0.30	0.25	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	+0.49	N/A	-1.60	+0.64	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page