

NORTH SEA STATION 62132, United Kingdom

WMO: 996790

Lat: 56.400N

Lon: 2.000E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (E00)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.4	35.4	N/A	N/A	N/A	N/A	N/A	N/A	43.5	44.0	40.9	43.6	14.1	80	0.792

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.6	68.5	N/A	66.5	N/A	64.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.1	34.2	30.8	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	43.8	42.7	42.9	46.6	50.7	54.9	59.1	61.4	57.9	53.1	49.3	45.1		
	DBStd	7.21	2.99	3.25	3.64	3.40	3.98	3.22	3.40	3.62	3.16	3.34	2.86	3.80		
	HDD50	980	192	204	221	112	38	3	0	0	0	10	44	156		
	HDD65	5243	657	624	685	552	445	304	186	120	213	369	470	618		
	CDD50	1225	0	0	1	10	58	148	282	355	238	107	24	2		
	CDD65	15	0	0	0	0	0	0	4	10	1	0	0	0		
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	15.9	20.4	18.4	16.8	13.9	13.8	12.6	11.7	13.3	14.3	17.5	19.0	19.0		
(15) Precipitation	PrecAvg	44.6	5.3	4.3	3.9	2.2	1.8	2.5	2.9	3.3	3.8	4.4	5.1	5.2		
	PrecMax	56.1	8.9	7.7	6.8	3.6	3.0	4.3	4.3	6.2	5.9	7.4	7.5	11.6		
	PrecMin	32.8	1.8	2.2	1.6	1.2	0.8	1.3	1.3	1.1	1.8	1.5	2.7	2.6		
	PrecStd	5.6	1.9	1.5	1.2	0.7	0.5	0.7	0.8	1.0	1.1	1.4	1.2	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	51.7	51.7	57.8	65.5	64.9	70.3	72.3	69.0	66.2	57.7	53.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	49.4	48.5	48.6	54.4	59.7	61.5	66.8	69.3	64.7	60.3	55.6	52.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	48.4	47.4	47.6	52.1	57.0	59.9	64.9	67.4	62.9	58.9	54.3	50.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	47.5	46.4	46.7	50.4	55.2	58.7	63.5	65.8	61.7	57.5	53.2	49.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.7	4.4	5.6	5.5	4.2	4.5	4.6	4.6	4.5	4.3	4.9		
		MCDBR	4.9	6.4	5.6	8.9	9.8	6.4	7.0	7.2	7.0	6.2	5.9	6.1		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.350	0.370	0.397	0.381	0.386	0.392	0.389	0.377	0.353	0.335	0.313		
	taud		2.219	2.299	2.310	2.275	2.402	2.412	2.406	2.419	2.432	2.395	2.272	2.201		
	Ebn at Noon		170	222	249	259	272	272	267	260	246	219	169	145		
	Edh at Noon		18	24	30	36	34	34	34	31	27	22	17	14		
(44) All-Sky Solar Radiation	RadAvg		138	341	756	1309	1772	1763	1659	1364	911	468	188	99		
	RadStd		15	47	68	97	117	106	166	90	104	31	19	12		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page