

SENTRY SHOAL BUOY 46131, BC, Canada

WMO: 996930

Lat: 49.910N

Lon: 124.990W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.8	(c) 33.5	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 36.3	(k) 44.6	(l) 33.7	(m) 44.9	(n) 12.6	(o) 320	(p) 0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.9	(c) 73.5	(d) N/A	(e) 71.0	(f) N/A	(g) 68.9	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 6.0	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 31.8	(b) 28.1	(c) 25.1	(e) 27.8	(f) 80.4	(g) 3.9	(h) 2.8	(i) 25.0	(j) 82.4	(k) 22.8	(l) 84.0	(m) 20.6	(n) 85.5	(o) 17.8	(p) 87.5		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	41.8	42.2	44.7	48.6	55.2	60.2	63.8	63.3	58.2	51.6	45.2	41.9
	DBStd	8.90	4.42	3.55	3.02	3.45	3.95	3.97	3.32	2.91	2.99	3.08	4.20	4.21
	HDD50	1124	253	220	165	65	5	0	0	0	0	17	148	251
	HDD65	4997	718	640	629	491	304	155	62	71	204	414	594	715
	CDD50	1658	0	0	1	24	167	306	429	412	246	68	4	1
	CDD65	57	0	0	0	0	1	11	26	18	1	0	0	0
	CDH74	60	0	0	0	0	1	17	34	8	0	0	0	0
	CDH80	4	0	0	0	0	0	1	2	1	0	0	0	0
(14) Wind	WSAvg	10.9	11.6	10.3	12.5	11.1	9.8	10.2	10.3	9.2	9.5	10.8	12.2	13.0
(15) Precipitation	PrecAvg	48.7	7.1	4.6	4.6	2.8	2.0	1.9	1.1	1.5	2.1	5.5	7.6	8.0
	PrecMax	66.1	14.3	13.0	9.3	6.4	4.7	4.2	2.1	5.3	7.1	13.4	14.7	13.3
	PrecMin	32.8	2.8	0.2	1.0	0.9	0.4	0.5	0.1	0.2	0.1	0.4	2.6	3.3
	PrecStd	8.2	2.7	2.8	2.0	1.6	1.0	1.0	0.6	1.1	1.7	3.1	3.6	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	50.5	52.6	62.1	69.0	76.4	77.9	74.7	69.1	60.6	54.4	52.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.8	48.9	51.0	58.6	65.3	71.8	73.9	72.3	66.1	58.7	52.7	50.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	48.5	47.6	49.6	55.6	62.7	68.3	71.3	70.2	64.2	57.1	51.5	48.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	47.4	46.6	48.6	53.3	60.6	65.7	69.1	68.3	62.5	55.6	50.4	47.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.6	5.2	6.6	7.5	8.1	8.9	8.2	6.4	4.7	4.4	4.2
		MCDBR	4.8	4.8	5.8	10.2	11.8	13.1	12.8	11.4	8.9	6.4	4.8	5.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.326	0.322	0.347	0.373	0.395	0.384	0.386	0.391	0.353	0.358	0.330	0.322
	taud		2.405	2.506	2.446	2.372	2.329	2.396	2.423	2.415	2.521	2.433	2.440	2.369
	Ebn at Noon		226	263	273	277	274	278	275	268	269	242	223	207
	Edh at Noon		21	23	30	35	38	36	35	33	27	25	20	18
(44) All-Sky Solar Radiation	RadAvg		251	526	783	1225	1607	1729	1905	1641	1139	609	296	197
	RadStd		38	90	110	130	177	196	208	138	102	106	58	30

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page