

E MAINE SHELF BUOY 44034, ME, USAWMO: **997181**Lat: **44.103N**Lon: **68.112W**Elev: **0**StdP: **14.70**Time Zone: **-5.00 (NAE)**Period: **05-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.2	14.5	N/A	N/A	N/A	N/A	N/A	N/A	39.8	27.6	37.0	29.0	21.2	320	0.742

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.9	63.5	N/A	62.3	N/A	61.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 34.3	31.3	26.7	DB	7.1	67.1	3.0	2.2	5.0	68.7	3.2	70.0	1.5	71.2	-0.7	72.8	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	30.9	30.1	34.1	41.0	46.2	51.7	56.7	58.4	57.1	51.7	44.8	36.5
	DBStd	11.20	9.14	6.83	6.09	3.15	2.89	2.92	2.77	2.17	2.61	4.14	6.16	7.84
	HDD50	2672	591	557	494	270	122	15	0	0	0	33	170	420
	HDD65	7293	1056	977	959	720	581	399	257	206	236	412	605	885
	CDD50	853	0	0	0	0	5	66	208	259	214	86	15	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.3	18.6	17.9	16.7	12.9	10.2	8.6	7.6	7.5	9.8	14.7	16.7	18.4
Precipitation	PrecAvg	54.8	4.5	3.8	4.9	4.7	4.3	4.1	3.3	2.8	4.4	5.7	5.9	5.7
	PrecMax	75.2	10.1	8.3	8.6	9.5	11.9	11.2	7.2	7.4	10.1	15.3	11.5	10.4
	PrecMin	29.1	0.4	1.4	1.2	0.3	0.9	1.5	0.9	0.6	1.1	1.4	2.8	2.3
	PrecStd	9.1	2.1	1.6	2.2	2.3	2.5	2.4	1.7	1.9	2.4	3.0	1.9	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.9	45.5	47.0	50.1	55.4	60.7	65.1	66.0	64.3	60.5	56.7	53.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	47.8	42.8	44.2	47.5	53.2	58.1	62.7	63.8	62.7	59.1	54.9	50.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	45.9	41.4	42.7	46.2	51.5	56.6	61.5	62.5	61.6	57.9	53.4	49.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	43.8	39.7	41.3	45.0	50.3	55.3	60.4	61.5	60.5	56.7	52.5	47.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	10.0	9.0	7.5	4.8	4.4	4.9	5.3	4.9	4.4	5.0	6.6	9.3
		MCDBR	9.9	9.6	7.4	6.1	6.1	6.7	6.9	6.2	5.4	5.1	6.0	10.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Clear-Sky Solar Irradiance	taub	0.302	0.310	0.330	0.359	0.381	0.419	0.435	0.410	0.367	0.339	0.321	0.305
taud		2.495	2.492	2.475	2.426	2.407	2.327	2.300	2.359	2.456	2.527	2.536	2.508	
Ebn at Noon		263	282	289	287	282	271	265	268	272	267	254	250	
Edh at Noon		22	26	30	35	36	40	40	37	31	25	21	20	
All-Sky Solar Radiation	RadAvg	481	764	1156	1464	1664	1803	1875	1678	1362	881	528	385	
	RadStd	41	63	80	151	199	155	134	93	82	82	50	41	

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page