

E MAINE SHELF BUOY 44034, ME, USAWMO: **997181**Lat: **44.103N**Lon: **68.112W**Elev: **0**StdP: **101.33**Time Zone: **-5.00 (NAE)**Period: **05-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.6	-9.7	N/A	N/A	N/A	N/A	N/A	N/A	17.8	-2.4	16.5	-1.7	9.5	320	0.742

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.7	17.5	N/A	16.8	N/A	16.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	14.0	11.9	DB	-13.8	19.5	1.7	1.2	-15.0	20.4	-16.0	21.1	-16.9	21.8	-18.2	22.7	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-0.6	-1.0	1.1	5.0	7.9	10.9	13.7	14.6	14.0	11.0	7.1	2.5
	DBStd	6.22	5.08	3.80	3.39	1.75	1.61	1.62	1.54	1.21	1.45	2.30	3.42	4.35
	HDD10.0	1484	328	309	274	150	68	8	0	0	0	18	94	233
	HDD18.3	4052	587	543	533	400	323	222	143	114	131	229	336	492
	CDD10.0	474	0	0	0	0	3	37	116	144	119	48	8	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.9	8.3	8.0	7.5	5.8	4.5	3.9	3.4	3.4	4.4	6.6	7.5	8.2
Precipitation	PrecAvg	1392	114	96	125	119	108	104	83	71	112	145	149	145
	PrecMax	1910	257	212	218	241	301	285	183	188	256	388	291	265
	PrecMin	738	11	35	30	8	23	39	24	14	29	36	71	58
	PrecStd	232	54	41	56	59	64	62	44	47	60	76	48	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	7.5	8.3	10.1	13.0	15.9	18.4	18.9	17.9	15.8	13.7	11.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	8.8	6.0	6.8	8.6	11.8	14.5	17.0	17.7	17.1	15.0	12.7	10.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	7.7	5.2	5.9	7.9	10.8	13.7	16.4	17.0	16.5	14.4	11.9	9.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	6.5	4.3	5.2	7.2	10.1	13.0	15.8	16.4	15.8	13.7	11.4	8.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.0	4.2	2.7	2.4	2.7	2.9	2.7	2.4	2.8	3.7	5.2
		MCDBR	5.5	5.3	4.1	3.4	3.4	3.7	3.8	3.5	3.0	2.8	3.4	5.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.302	0.310	0.330	0.359	0.381	0.419	0.435	0.410	0.367	0.339	0.321	0.305
	taud		2.495	2.492	2.475	2.426	2.407	2.327	2.300	2.359	2.456	2.527	2.536	2.508
	Ebn at Noon		829	888	911	905	890	853	834	844	859	842	800	789
	Edh at Noon		70	83	96	109	115	125	127	116	97	80	67	63
All-Sky Solar Radiation	RadAvg		1.52	2.41	3.64	4.62	5.25	5.68	5.91	5.29	4.29	2.78	1.67	1.21
	RadStd		0.13	0.20	0.25	0.48	0.63	0.49	0.42	0.29	0.26	0.26	0.16	0.13

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page