

SOUTH SANTA ROSA ISLAND, CA, USA

WMO: 997199

Lat: 33.677N

Lon: 120.213W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (W08)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.9	10.3	N/A	N/A	N/A	N/A	N/A	N/A	16.2	11.7	15.6	11.6	8.1	330	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.5	20.5	N/A	19.9	N/A	19.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.4	320

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
14.7	14.0	13.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	13.5	12.9	12.8	12.6	13.1	13.8	15.4	15.9	16.4	16.2	15.1	13.7
	DBStd	2.03	1.60	1.46	1.45	1.18	1.34	1.11	1.78	1.48	1.76	1.81	1.50	1.48
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1493	151	153	171	173	162	137	92	77	64	73	97	143
	CDD10.0	1564	107	81	88	78	96	113	168	182	192	191	154	116
	CDD18.3	14	0	0	0	0	1	0	2	1	6	5	1	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.3	6.3	6.7	7.2	8.2	8.5	8.2	7.3	7.6	7.4	6.6	6.6	6.4
Precipitation	PrecAvg	356	70	75	54	27	14	4	3	2	4	17	30	55
	PrecMax	722	310	328	247	97	60	18	13	9	17	83	99	184
	PrecMin	116	5	4	1	6	3	0	0	0	0	2	5	5
	PrecStd	141	67	67	53	24	13	4	3	2	3	18	23	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.6	18.2	17.9	16.9	18.6	19.1	20.2	19.8	21.7	21.4	19.7	18.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	17.3	16.3	16.4	15.2	16.1	16.3	19.6	18.9	20.7	20.3	18.5	17.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	16.4	15.5	15.4	14.5	15.3	15.6	18.9	18.5	20.0	19.8	17.7	16.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	15.7	14.8	14.9	14.1	14.8	15.2	18.2	18.0	19.1	19.1	17.1	15.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.8	1.6	1.6	1.4	1.4	1.4	1.4	1.3	1.5	1.6	1.6	1.5
		MCDBR	2.8	2.3	2.1	1.9	2.1	1.8	1.7	1.5	1.8	2.2	2.5	1.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.305	0.316	0.329	0.351	0.358	0.347	0.368	0.351	0.345	0.345	0.309	0.309	
	taud	2.625	2.609	2.561	2.480	2.484	2.514	2.509	2.526	2.550	2.551	2.628	2.623	
	Ebn at Noon	919	942	950	936	927	932	910	924	919	895	906	894	
	Edh at Noon	76	85	96	109	110	106	106	103	96	89	75	72	
All-Sky Solar Radiation	RadAvg	3.12	3.97	5.21	6.39	6.57	6.25	5.81	5.53	5.15	4.17	3.40	2.81	
	RadStd	0.22	0.34	0.35	0.41	0.69	0.41	0.44	0.48	0.45	0.48	0.24	0.24	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days		
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.64	N/A	-1.43	+0.85	N/A	N/A	N/A	-133	+240	+84

Nomenclature: See separate page