

SAN CLEMENTE BASIN BUOY 46086, CA, USA

WMO: 997206

Lat: 32.499N

Lon: 118.052W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (W08)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	52.6	53.2	N/A	N/A	N/A	N/A	N/A	N/A	29.2	55.4	25.0	55.5	11.8	290	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.6	73.4	N/A	71.7	N/A	70.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.6	21.7	19.4	DB	50.5	74.2	2.3	3.1	48.9	76.4	47.5	78.3	46.2	80.0	44.5	82.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	58.5	57.5	57.9	58.3	59.6	60.7	63.9	65.2	66.2	65.1	62.2	58.9
	DBStd	4.04	2.58	2.46	2.60	2.29	2.04	2.09	2.83	2.63	3.22	3.34	2.69	2.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1560	201	209	220	201	168	129	57	32	22	42	91	188
	CDD50	4090	264	211	246	249	299	321	430	471	487	468	367	277
	CDD65	174	0	0	1	0	2	1	22	37	59	44	8	0
	CDH74	25	0	0	0	0	0	0	1	0	11	13	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.9	8.8	10.1	10.5	11.1	11.0	9.6	9.4	9.8	9.8	9.2	9.1	10.0
Precipitation	PrecAvg	3.8	0.5	0.6	0.4	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.6
	PrecMax	7.2	1.6	1.9	1.6	0.8	0.7	0.8	1.1	0.8	1.1	1.2	1.1	1.3
	PrecMin	2.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	PrecStd	1.2	0.4	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.7	65.3	67.2	66.9	70.3	67.2	73.2	72.1	75.8	75.8	70.4	66.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	64.0	63.1	64.4	64.2	65.7	65.8	71.1	70.4	73.7	73.3	68.5	65.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	62.9	61.9	62.5	62.7	63.3	64.8	69.5	69.2	72.0	71.3	67.3	64.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	62.0	60.8	61.4	61.4	62.1	63.8	68.2	68.5	70.7	70.0	66.1	62.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.2	2.9	3.0	2.9	2.7	2.8	2.4	2.2	2.6	2.8	2.9	2.7
		MCDBR	4.0	3.9	4.1	4.2	3.8	3.3	2.8	2.4	3.1	4.0	3.9	3.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.307	0.319	0.331	0.346	0.361	0.360	0.379	0.371	0.349	0.347	0.315	0.312	
	taud	2.616	2.594	2.546	2.494	2.473	2.475	2.491	2.491	2.550	2.549	2.612	2.620	
	Ebn at Noon	293	299	301	299	293	292	286	288	292	285	287	285	
	Edh at Noon	24	28	31	34	35	35	34	34	31	29	24	23	
All-Sky Solar Radiation	RadAvg	1031	1295	1650	1986	1946	1860	1919	1901	1702	1359	1098	933	
	RadStd	60	95	113	140	199	167	178	144	140	129	99	75	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		+1.19	N/A	-2.88	+1.48	N/A	N/A	-212	+423	+207

Nomenclature: See separate page