

SAN CLEMENTE BASIN BUOY 46086, CA, USA

WMO: 997206

Lat: 32.499N

Lon: 118.052W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (W08)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.4	11.8	N/A	N/A	N/A	N/A	N/A	N/A	13.0	13.0	11.2	13.1	5.3	290	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 1.5	(c) 23.0	(d) N/A	(e) 22.1	(f) N/A	(g) 21.4	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.6	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.7	8.7	DB	10.3	23.4	1.3	1.7	9.4	24.7	8.6	25.7	7.9	26.7	7.0	28.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	14.7	14.2	14.4	14.6	15.4	15.9	17.7	18.4	19.0	18.4	16.8	15.0
	DBStd	2.24	1.43	1.36	1.44	1.27	1.13	1.16	1.57	1.46	1.79	1.85	1.49	1.45
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	867	112	116	122	112	93	72	32	18	12	23	51	104
	CDD10.0	2272	147	117	137	138	166	178	239	262	271	260	204	154
	CDD18.3	97	0	0	1	0	1	1	12	21	33	24	4	0
	CDH23.3	14	0	0	0	0	0	0	1	0	6	7	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.4	3.9	4.5	4.7	5.0	4.9	4.3	4.2	4.4	4.4	4.1	4.1	4.5
Precipitation	PrecAvg	97	13	15	10	5	6	5	4	4	7	7	8	14
	PrecMax	183	41	47	41	21	17	20	29	21	29	31	29	33
	PrecMin	50	1	2	1	1	0	1	0	0	0	1	2	1
	PrecStd	30	10	12	8	5	5	4	5	4	6	6	6	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	18.5	19.5	19.4	21.3	19.5	22.9	22.3	24.3	24.3	21.3	19.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	17.8	17.3	18.0	17.9	18.7	18.8	21.7	21.3	23.2	22.9	20.3	18.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	17.2	16.6	17.0	17.1	17.4	18.2	20.8	20.7	22.2	21.8	19.6	17.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	16.7	16.0	16.3	16.4	16.7	17.7	20.1	20.3	21.5	21.1	18.9	17.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.8	1.6	1.7	1.6	1.5	1.5	1.3	1.2	1.5	1.6	1.6	1.5
		MCDBR	2.2	2.2	2.3	2.3	2.1	1.9	1.5	1.4	1.7	2.2	2.1	1.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.307	0.319	0.331	0.346	0.361	0.360	0.379	0.371	0.349	0.347	0.315	0.312	
	taud	2.616	2.594	2.546	2.494	2.473	2.475	2.491	2.491	2.550	2.549	2.612	2.620	
	Ebn at Noon	923	942	950	943	925	921	901	907	919	897	905	898	
	Edh at Noon	77	87	98	108	111	111	108	107	97	90	77	74	
All-Sky Solar Radiation	RadAvg	3.25	4.08	5.20	6.26	6.13	5.87	6.05	5.99	5.37	4.28	3.46	2.94	
	RadStd	0.19	0.30	0.36	0.44	0.63	0.53	0.56	0.46	0.44	0.41	0.31	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	+0.66	N/A	-1.60	+0.82	N/A	N/A	N/A	-118	+235	+115

Nomenclature: See separate page