

ATLANTIC CITY BOARDWALK, NJ, USA

WMO: 997270

Lat: 39.357N

Lon: 74.418W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.9	(c) -7.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 11.3	(k) -0.4	(l) 10.5	(m) -0.8	(n) 1.2	(o) 350	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 4.7	(c) 30.1	(d) N/A	(e) 28.2	(f) N/A	(g) 26.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.0	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 10.9	(b) 9.2	(c) 8.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	1.2	2.7	5.3	10.6	15.6	20.8	24.0	23.6	21.0	15.5	9.3	5.2		
	DBStd	8.72	5.16	4.35	3.89	3.61	3.04	2.92	2.23	1.93	2.70	3.52	4.05	4.51		
	HDD10.0	886	273	207	152	34	1	0	0	0	0	3	60	157		
	HDD18.3	2495	530	439	404	234	94	9	0	0	8	99	271	406		
	CDD10.0	1969	1	1	6	52	174	326	433	423	329	174	39	9		
	CDD18.3	536	0	0	0	2	10	85	174	164	88	12	0	0		
	CDH23.3	2203	0	0	0	9	14	293	907	750	214	15	0	0		
	CDH26.7	356	0	0	0	1	1	66	171	98	17	2	0	0		
(14) Wind	WSAvg	2.3	2.1	2.3	2.8	3.1	2.3	2.0	1.5	1.9	2.1	2.8	2.8	2.5		
(15) Precipitation	PrecAvg	1025	83	73	99	88	81	71	94	109	79	77	83	85		
	PrecMax	1436	213	160	215	190	172	208	317	421	174	244	216	174		
	PrecMin	650	9	14	8	23	8	17	16	26	5	0	22	18		
	PrecStd	148	41	31	47	42	42	44	55	76	43	47	51	40		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	14.8	17.7	24.7	25.5	31.3	33.0	31.4	28.6	25.3	18.5	15.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	10.7	11.2	14.1	20.4	22.9	28.5	30.5	29.4	26.3	22.4	16.9	14.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	9.3	9.0	12.0	17.3	21.1	26.5	28.4	27.4	25.3	21.4	15.8	12.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	7.9	7.8	10.4	15.2	19.8	24.7	26.9	26.2	24.6	20.5	15.0	11.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		6.1	6.1	5.9	5.8	5.2	5.1	4.7	4.2	4.3	5.3	5.8	5.7		
	5% DB	MCDBR	7.0	7.2	8.4	9.5	7.5	8.5	7.5	6.5	5.2	6.3	5.9	5.7		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.318	0.323	0.355	0.387	0.433	0.488	0.498	0.491	0.411	0.365	0.333	0.318		
	taud		2.500	2.489	2.432	2.366	2.270	2.157	2.140	2.152	2.350	2.482	2.521	2.539		
	Ebn at Noon		854	902	902	889	850	802	789	784	831	841	830	829		
	Edh at Noon		77	89	105	119	134	150	151	146	113	89	76	70		
(44) All-Sky Solar Radiation	RadAvg		2.00	2.90	3.93	5.04	5.61	6.15	6.22	5.49	4.49	3.23	2.29	1.77		
	RadStd		0.18	0.32	0.32	0.39	0.66	0.52	0.31	0.38	0.41	0.31	0.21	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+126	+73

Nomenclature: See separate page