

NEW YORK BERGEN POINT, NY, USA

WMO: 997272

Lat: 40.639N

Lon: 74.146W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.9	(c) 18.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 26.4	(k) 29.1	(l) 23.9	(m) 30.0	(n) 6.7	(o) 320	(p) 0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.0	(c) 91.9	(d) N/A	(e) 89.2	(f) N/A	(g) 86.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 5.6	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 21.7	(b) 18.7	(c) 16.5	(e) 10.1	(f) 96.1	(g) 5.0	(h) 2.1	(i) 6.5	(j) 97.6	(k) 3.6	(l) 98.8	(m) 0.8	(n) 100.0	(o) -2.8	(p) 101.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.8	33.6	34.5	41.8	53.8	63.1	72.1	78.1	75.9	69.0	58.5	47.7	39.6		
	DBStd	17.08	9.11	8.57	8.25	7.76	7.25	6.48	4.69	4.49	5.72	7.28	7.59	8.31		
	HDD50	1753	511	438	277	42	1	0	0	0	0	13	132	339		
	HDD65	4589	973	853	718	350	127	13	0	1	22	225	520	787		
	CDD50	3854	3	5	24	154	406	663	871	802	571	277	62	16		
	CDD65	1216	0	0	0	12	67	226	406	338	143	24	0	0		
	CDH74	9340	0	1	1	109	494	1711	3683	2478	752	111	0	0		
	CDH80	3025	0	0	0	30	130	569	1367	726	184	19	0	0		
(14) Wind	WSAvg	5.7	5.9	6.5	7.3	6.4	5.2	4.7	4.3	4.5	5.5	5.5	6.2	6.1		
(15) Precipitation	PrecAvg	43.7	3.3	2.9	4.0	3.7	4.1	3.4	4.4	4.0	3.9	2.9	3.6	3.5		
	PrecMax	65.5	10.1	5.0	11.1	11.1	10.2	10.5	10.0	10.6	9.4	6.8	11.5	9.4		
	PrecMin	26.1	0.4	0.5	1.1	0.9	0.5	0.4	0.9	0.5	1.0	0.2	0.5	0.6		
	PrecStd	8.4	2.0	1.1	2.0	2.0	2.1	1.9	2.5	2.2	2.2	1.5	2.3	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	64.3	71.1	84.7	88.7	93.9	95.5	93.4	89.9	82.7	69.8	67.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	57.6	56.8	63.8	76.3	83.7	89.8	92.6	89.7	85.1	77.0	65.5	60.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	51.2	50.3	58.6	71.2	79.7	86.4	90.0	86.8	81.5	72.5	62.0	56.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	46.4	45.5	53.9	66.3	75.6	82.8	87.3	84.2	78.0	69.1	59.3	51.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.6	13.2	15.2	15.1	13.9	14.0	13.0	13.0	13.3	12.5	10.7		
		MCDBR	18.6	19.3	20.7	23.3	20.6	18.5	17.2	16.7	17.0	17.7	16.6	15.7		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.328	0.362	0.385	0.432	0.491	0.493	0.480	0.403	0.364	0.332	0.315		
	taud		2.464	2.428	2.393	2.360	2.261	2.131	2.142	2.169	2.356	2.475	2.519	2.524		
	Ebn at Noon		268	281	282	282	270	253	251	251	265	265	260	259		
	Edh at Noon		25	30	34	38	43	49	48	45	35	28	23	22		
(44) All-Sky Solar Radiation	RadAvg		594	881	1183	1522	1687	1854	1891	1641	1367	955	671	508		
	RadStd		51	90	99	148	177	168	92	107	135	96	59	49		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+211	+122

Nomenclature: See separate page