

NEW YORK BERGEN POINT, NY, USA

WMO: 997272

Lat: 40.639N

Lon: 74.146W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.5	(c) -7.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 11.8	(k) -1.6	(l) 10.7	(m) -1.1	(n) 3.0	(o) 320	(p) 0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.8	(c) 33.3	(d) N/A	(e) 31.8	(f) N/A	(g) 30.4	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.5	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.7	(b) 8.4	(c) 7.4	(e) -12.2	(f) 35.6	(g) 2.8	(h) 1.2	(i) -14.2	(j) 36.4	(k) -15.8	(l) 37.1	(m) -17.3	(n) 37.8	(o) -19.4	(p) 38.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	0.9	1.4	5.5	12.1	17.3	22.3	25.6	24.4	20.6	14.7	8.7	4.2		
	DBStd	9.49	5.06	4.76	4.59	4.31	4.03	3.60	2.61	2.50	3.18	4.04	4.21	4.61		
	HDD10.0	974	284	243	154	23	1	0	0	0	0	7	73	188		
	HDD18.3	2549	541	474	399	194	71	7	0	1	12	125	289	437		
	CDD10.0	2141	2	3	13	86	226	368	484	446	317	154	34	9		
	CDD18.3	676	0	0	0	7	37	126	226	188	79	13	0	0		
	CDH23.3	5189	0	1	1	61	274	951	2046	1377	418	62	0	0		
	CDH26.7	1681	0	0	0	17	72	316	759	403	102	11	0	0		
(14) Wind	WSAvg	2.5	2.6	2.9	3.3	2.8	2.3	2.1	1.9	2.0	2.5	2.4	2.8	2.7		
(15) Precipitation	PrecAvg	1110	85	74	102	94	104	86	111	102	99	73	92	88		
	PrecMax	1664	256	126	283	283	260	267	254	270	238	172	293	240		
	PrecMin	663	11	13	28	23	13	10	23	13	26	5	13	16		
	PrecStd	213	51	29	50	50	54	49	63	55	55	39	59	47		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	17.9	21.7	29.3	31.5	34.4	35.3	34.1	32.2	28.2	21.0	19.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	14.2	13.8	17.7	24.6	28.7	32.1	33.7	32.0	29.5	25.0	18.6	15.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	10.7	10.2	14.8	21.8	26.5	30.2	32.2	30.4	27.5	22.5	16.7	13.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	8.0	7.5	12.2	19.1	24.2	28.2	30.7	29.0	25.5	20.6	15.2	10.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		6.6	7.0	7.4	8.5	8.4	7.7	7.8	7.2	7.2	7.4	6.9	5.9		
	5% DB	MCDBR	10.4	10.7	11.5	12.9	11.4	10.3	9.6	9.3	9.4	9.8	9.2	8.7		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.328	0.362	0.385	0.432	0.491	0.493	0.480	0.403	0.364	0.332	0.315		
	taud		2.464	2.428	2.393	2.360	2.261	2.131	2.142	2.169	2.356	2.475	2.519	2.524		
	Ebn at Noon		844	885	889	888	850	797	791	790	834	834	819	818		
	Edh at Noon		78	93	108	119	134	153	151	143	111	88	74	69		
(44) All-Sky Solar Radiation	RadAvg		1.87	2.78	3.73	4.80	5.32	5.84	5.96	5.17	4.31	3.01	2.11	1.60		
	RadStd		0.16	0.28	0.31	0.47	0.56	0.53	0.29	0.34	0.42	0.30	0.18	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	+68

Nomenclature: See separate page