

CONIMUCUT LIGHT, RI, USA

WMO: 997277

Lat: 41.7170N

Lon: 71.3451W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	15.4	N/A	N/A	N/A	N/A	N/A	N/A	49.6	24.2	43.2	23.6	21.4	290	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	84.4	N/A	81.7	N/A	79.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	38.2	31.8	26.7	DB	6.8	90.2	4.5	4.0	3.5	93.1	0.9	95.4	-1.7	97.6	-4.9	100.5
(5)				WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	30.4	31.9	38.3	48.8	57.4	66.8	74.5	72.0	65.7	55.9	45.8	37.0
	DBStd	16.30	8.93	7.79	7.21	5.75	6.05	5.73	3.79	3.91	5.04	6.29	7.22	7.88
	HDD50	2169	606	508	367	87	7	0	0	0	0	20	164	410
	HDD65	5388	1071	928	827	485	246	45	0	2	52	287	576	869
	CDD50	2959	0	0	5	53	237	505	760	681	471	204	38	5
	CDD65	702	0	0	0	0	11	100	295	218	73	5	0	0
	CDH74	2992	0	0	0	6	38	342	1579	870	148	9	0	0
	CDH80	443	0	0	0	0	6	62	280	89	6	0	0	0
Wind	WSAvg	13.0	14.8	14.6	16.0	14.9	12.8	11.8	11.0	10.6	11.3	12.4	12.7	13.1
Precipitation	PrecAvg	45.4	3.9	3.5	4.3	4.0	3.6	3.3	2.9	3.7	3.9	3.8	4.3	4.3
	PrecMax	67.5	11.7	7.2	8.8	12.8	8.4	11.1	8.1	10.1	7.9	15.4	11.0	10.7
	PrecMin	25.4	0.5	0.4	0.6	1.5	0.7	0.2	0.4	0.7	0.9	0.4	0.4	1.0
	PrecStd	7.6	2.2	1.5	2.0	2.0	1.8	2.2	1.6	2.2	1.9	2.8	2.1	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	51.5	61.5	71.4	78.4	86.3	89.2	87.7	80.4	74.9	64.2	59.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.4	48.2	54.6	63.7	72.6	80.9	85.8	82.2	77.7	70.2	60.7	54.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	46.2	44.8	50.7	59.7	69.1	77.7	83.0	80.1	75.5	67.3	58.4	52.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	42.8	42.3	47.9	57.1	66.4	75.1	80.6	78.4	73.6	65.0	56.4	49.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	11.6	11.5	11.2	11.2	11.3	10.9	10.4	10.4	11.0	10.9	10.7	10.2
		MCDBR	15.9	13.3	14.1	14.9	14.7	14.2	12.5	11.8	11.4	11.7	11.2	12.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.299	0.308	0.333	0.372	0.413	0.460	0.484	0.441	0.374	0.339	0.312	0.299	
	taud	2.502	2.483	2.464	2.384	2.301	2.209	2.151	2.261	2.423	2.530	2.565	2.560	
	Ebn at Noon	272	287	291	285	274	260	252	261	273	272	266	263	
	Edh at Noon	23	27	31	36	41	45	47	41	32	26	22	20	
All-Sky Solar Radiation	RadAvg	589	867	1187	1527	1691	1845	1905	1712	1392	937	641	492	
	RadStd	43	82	85	163	170	182	103	88	101	85	47	49	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (68 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	+85

Nomenclature: See separate page