

NEW YORK KINGS POINT, NY, USA

WMO: 997280

Lat: 40.811N

Lon: 73.765W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.8	(c) -7.5	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 13.9	(k) -1.1	(l) 12.2	(m) 0.4	(n) 6.4	(o) 20	(p) 0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.8	(c) 31.2	(d) N/A	(e) 29.8	(f) N/A	(g) 28.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.8	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 12.2	(b) 10.5	(c) 8.9	(e) -11.8	(f) 34.1	(g) 2.3	(h) 1.5	(i) -13.4	(j) 35.1	(k) -14.8	(l) 36.0	(m) -16.1	(n) 36.8	(o) -17.8	(p) 37.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.8	0.5	1.5	4.8	11.0	16.2	21.3	24.6	24.1	20.8	15.2	9.0	4.3		
	DBStd	9.19	4.97	4.16	4.17	3.53	3.53	3.14	2.30	2.19	2.98	3.75	4.11	4.34		
	HDD10.0	984	294	239	168	28	1	0	0	0	0	4	67	184		
	HDD18.3	2599	552	471	419	221	87	10	0	1	10	111	281	436		
	CDD10.0	2016	1	1	7	58	192	338	453	436	324	165	36	6		
	CDD18.3	589	0	0	0	2	19	97	195	178	84	14	0	0		
	CDH23.3	3519	0	0	0	13	86	511	1378	1105	377	49	1	0		
	CDH26.7	805	0	0	0	2	13	112	368	241	59	11	0	0		
(14) Wind	WSAvg	3.8	4.6	4.6	4.6	3.9	3.4	3.2	3.1	2.8	3.1	3.8	4.3	4.4		
(15) Precipitation	PrecAvg	1042	81	69	96	96	98	91	93	91	87	72	84	87		
	PrecMax	1502	212	124	208	242	272	234	215	211	245	167	242	171		
	PrecMin	645	12	12	24	35	16	5	14	11	24	11	8	16		
	PrecStd	187	50	30	41	44	51	56	52	54	51	39	55	45		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	14.8	18.1	25.4	28.4	31.8	33.7	32.5	30.4	28.1	19.8	16.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	11.7	11.1	15.0	21.1	25.6	29.5	31.6	30.5	28.4	24.2	17.4	14.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	9.8	8.9	12.6	18.6	23.6	27.7	30.1	29.1	26.8	22.0	16.2	12.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	7.5	7.1	10.5	16.4	21.8	26.2	28.8	27.9	25.5	20.4	15.0	10.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.5	6.7	7.7	7.5	7.1	6.8	6.6	6.7	6.6	6.2	5.6		
		MCDBR	9.0	9.0	9.3	11.4	10.0	9.3	8.8	8.4	7.9	9.0	7.4	7.6		
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.330	0.361	0.385	0.433	0.489	0.496	0.478	0.403	0.364	0.333	0.319		
	taud		2.452	2.426	2.397	2.365	2.259	2.142	2.134	2.175	2.356	2.479	2.518	2.515		
	Ebn at Noon		837	881	889	888	848	798	788	790	833	833	816	811		
	Edh at Noon		78	93	107	118	135	152	152	142	111	88	74	69		
(44) All-Sky Solar Radiation	RadAvg		1.86	2.75	3.76	4.82	5.36	5.88	5.99	5.28	4.34	3.01	2.10	1.58		
	RadStd		0.15	0.27	0.31	0.48	0.54	0.55	0.30	0.34	0.39	0.30	0.18	0.15		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+66

Nomenclature: See separate page