

LEWES HARBOR, DE, USA

WMO: 997281

Lat: 38.7834N

Lon: 75.1191W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.4	21.8	N/A	N/A	N/A	N/A	N/A	N/A	39.2	26.8	35.8	26.9	17.3	330	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	91.0	N/A	88.4	N/A	85.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.9	30.3	26.3	DB	12.1	95.2	4.3	3.0	9.0	97.4	6.4	99.1	4.0	100.8	0.9	103.0	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	37.1	38.1	44.1	55.0	64.2	73.3	78.1	76.4	70.5	61.1	50.0	43.4
	DBStd	16.19	9.95	8.93	8.26	8.34	7.61	6.00	4.46	4.16	5.29	6.96	7.86	8.84
	HDD50	1372	417	349	222	36	0	0	0	0	0	5	96	247
	HDD65	3996	865	754	647	320	111	6	0	0	12	158	451	672
	CDD50	4189	17	15	41	187	441	698	870	817	615	351	96	41
	CDD65	1336	0	0	0	21	87	253	405	352	178	38	1	1
	CDH74	8655	0	0	3	143	512	1662	3231	2249	740	115	0	0
	CDH80	2539	0	0	0	41	129	538	1069	589	154	19	0	0
Wind	WSAvg	10.9	12.7	13.1	13.1	12.1	9.8	9.2	7.5	7.7	9.6	11.4	12.4	12.0
Precipitation	PrecAvg	45.3	3.5	2.8	4.4	3.3	3.5	3.7	4.4	4.2	4.1	3.8	3.4	3.6
	PrecMax	57.8	6.3	5.9	7.8	5.5	6.8	9.2	8.3	8.4	7.4	8.0	6.6	7.9
	PrecMin	38.8	1.0	0.9	0.3	1.4	1.0	1.7	1.7	0.7	0.4	0.2	0.6	1.8
	PrecStd	5.4	1.3	1.3	1.8	1.1	1.7	1.8	1.8	1.9	2.0	2.2	1.9	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.1	69.0	73.0	85.8	88.2	93.9	95.3	93.8	88.4	82.3	72.3	70.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	62.1	62.6	67.3	77.7	83.6	89.5	91.4	89.4	84.2	77.1	67.6	66.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	58.0	57.1	61.8	72.6	79.9	86.0	88.7	86.1	80.9	74.0	64.2	61.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	52.2	50.8	56.8	68.1	75.8	82.5	85.9	82.9	78.0	71.0	61.1	56.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	12.3	12.4	12.4	13.7	13.3	12.3	12.6	10.5	10.2	11.4	11.5	11.7
		MCDBR	20.4	21.1	22.3	20.8	19.0	18.3	16.6	15.9	14.5	14.8	15.3	17.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.317	0.320	0.359	0.392	0.442	0.488	0.505	0.501	0.414	0.362	0.329	0.316	
	taud	2.499	2.493	2.415	2.345	2.239	2.154	2.123	2.119	2.342	2.490	2.530	2.539	
	Ebn at Noon	273	288	285	281	268	254	249	246	264	269	266	265	
	Edh at Noon	25	28	34	39	44	48	49	48	36	28	24	23	
All-Sky Solar Radiation	RadAvg	663	934	1261	1615	1822	1992	1957	1743	1426	1058	755	583	
	RadStd	58	98	104	120	204	156	96	115	141	105	69	56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+250	+148

Nomenclature: See separate page