

NEW HAVEN HARBOR, CT, USA

WMO: 997284

Lat: 41.283N

Lon: 72.908W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.7	15.7	N/A	N/A	N/A	N/A	N/A	N/A	28.7	26.3	27.0	26.9	12.4	310	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	84.0	N/A	81.5	N/A	79.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4)	26.8	23.5	20.1	DB	7.3	90.3	3.7	2.9	4.6	92.3	2.5	94.0	0.4	95.7	-2.3	97.8
(5)				WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	30.4	32.1	38.9	49.6	58.9	68.0	73.9	72.5	66.3	56.3	45.0	37.5
	DBStd	16.40	8.68	7.65	7.23	6.28	5.72	5.35	4.28	3.94	5.61	6.58	7.22	7.75
	HDD50	2136	607	503	349	81	3	0	0	0	0	19	182	392
	HDD65	5285	1072	923	810	462	204	30	1	1	52	279	599	852
	CDD50	3073	0	0	5	69	279	539	742	697	490	214	33	5
	CDD65	746	0	0	0	0	15	119	278	233	92	9	0	0
	CDH74	3015	0	0	0	2	35	341	1360	1009	249	19	0	0
	CDH80	400	0	0	0	0	7	53	223	106	8	3	0	0
Wind	WSAvg	9.1	9.9	10.0	10.6	9.3	8.6	8.5	8.3	7.6	8.3	9.2	9.7	9.5
Precipitation	PrecAvg	41.9	2.9	3.1	3.5	3.9	3.9	3.5	3.5	3.1	3.4	3.5	4.0	3.8
	PrecMax	57.4	6.1	5.3	9.2	10.7	10.6	12.7	8.7	7.8	7.7	8.3	8.7	7.7
	PrecMin	27.7	0.2	0.6	0.7	1.4	0.8	0.2	0.8	0.7	0.9	0.3	0.4	1.0
	PrecStd	8.3	1.6	1.1	1.8	2.0	2.4	2.8	2.1	1.8	2.0	2.0	2.3	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	52.9	60.5	72.3	78.0	85.6	89.5	86.3	81.3	76.4	64.2	57.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.4	47.4	55.1	65.8	73.0	80.7	85.0	82.6	78.9	70.6	60.8	54.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	45.9	44.7	51.6	61.8	69.9	77.7	82.1	80.6	77.0	68.4	58.9	51.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	42.7	42.1	48.7	58.6	67.4	75.2	80.0	78.9	75.0	66.2	56.7	49.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	11.8	11.9	11.8	12.6	12.2	11.4	10.5	10.9	12.2	12.2	11.9	10.4
		MCDBR	14.8	14.2	15.1	17.4	15.3	13.9	12.7	12.0	11.6	13.1	12.8	12.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.308	0.317	0.341	0.376	0.425	0.470	0.487	0.461	0.389	0.349	0.319	0.306	
	taud	2.472	2.452	2.439	2.372	2.264	2.177	2.139	2.205	2.379	2.507	2.543	2.538	
	Ebn at Noon	269	284	289	284	271	258	252	255	268	269	264	261	
	Edh at Noon	24	29	32	37	43	46	48	43	34	27	23	21	
All-Sky Solar Radiation	RadAvg	587	863	1180	1524	1702	1855	1894	1684	1383	934	651	490	
	RadStd	47	79	93	161	168	180	103	101	113	90	53	45	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+193	+104

Nomenclature: See separate page