

FORT PULASKI, GA, USA

WMO: 997301

Lat: 32.035N

Lon: 80.903W

Elev: 20

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.6	(c) 35.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 29.0	(k) 45.8	(l) 26.3	(m) 47.9	(n) 13.5	(o) 310	(p) 0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.7	(c) 91.0	(d) N/A	(e) 89.0	(f) N/A	(g) 87.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 8.0	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.6	(b) 22.2	(c) 19.3	(e) 26.5	(f) 95.1	(g) 4.2	(h) 1.1	(i) 23.4	(j) 95.9	(k) 21.0	(l) 96.6	(m) 18.6	(n) 97.2	(o) 15.5	(p) 98.0		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.2	49.8	53.2	57.7	66.5	73.9	80.2	81.7	81.5	77.7	69.8	58.3	55.4		
	DBStd	12.82	8.34	7.82	7.71	5.69	4.46	3.20	2.55	2.67	3.75	5.72	6.86	7.64		
	HDD50	238	107	54	25	1	0	0	0	0	0	0	14	37		
	HDD65	1651	473	336	244	50	2	0	0	0	0	25	215	306		
	CDD50	6516	100	142	262	496	741	905	983	977	830	613	264	203		
	CDD65	2456	1	4	17	95	278	455	518	512	380	173	15	8		
	CDH74	20946	1	5	35	202	1357	4384	5595	5521	3157	672	14	3		
	CDH80	5552	0	0	3	13	212	1243	1761	1697	577	46	0	0		
(14) Wind	WSAvg	8.8	9.3	9.1	9.7	9.3	8.9	7.9	7.7	7.5	9.1	9.0	9.3	8.6		
(15) Precipitation	PrecAvg	47.3	3.2	3.2	3.5	2.9	2.9	5.3	5.5	6.2	4.8	4.4	2.4	2.9		
	PrecMax	68.5	9.1	10.8	8.5	7.1	7.6	12.7	9.6	15.4	9.0	20.4	5.4	10.3		
	PrecMin	32.4	0.4	0.3	0.2	0.5	0.4	1.3	1.2	2.2	0.7	0.1	0.0	0.7		
	PrecStd	8.5	2.2	2.2	1.9	1.9	2.0	2.4	2.2	2.7	2.0	3.9	1.7	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.0	74.7	78.6	82.0	89.4	93.0	93.2	93.2	88.8	83.7	76.2	73.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	67.0	69.9	73.6	78.4	84.9	90.3	90.6	90.3	86.2	81.3	73.5	70.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	64.1	66.5	70.6	76.4	82.1	88.0	88.5	88.2	84.5	79.4	71.1	68.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	61.4	63.4	67.7	74.4	79.9	86.0	86.8	86.4	83.1	77.7	68.6	65.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	12.6	12.3	11.1	9.3	10.2	9.7	9.3	8.2	10.6	12.0	12.0		
		MCDBR	14.8	15.5	14.9	12.7	12.6	13.3	12.7	12.1	10.4	11.3	14.1	13.2		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.340	0.370	0.402	0.451	0.491	0.522	0.505	0.429	0.396	0.357	0.344		
	taud		2.533	2.511	2.445	2.349	2.249	2.190	2.114	2.164	2.371	2.433	2.497	2.524		
	Ebn at Noon		283	292	289	282	268	256	247	250	266	268	271	272		
	Edh at Noon		27	30	35	40	44	47	50	47	37	32	28	26		
(44) All-Sky Solar Radiation	RadAvg		940	1147	1510	1906	2052	2041	2002	1811	1525	1330	1041	833		
	RadStd		54	119	139	124	124	153	118	116	131	139	69	65		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (34 neighbors)		+1.04	N/A	N/A	N/A	N/A	N/A	N/A	-157	+349	+239	

Nomenclature: See separate page