

FORT PULASKI, GA, USA

WMO: 997301

Lat: 32.035N

Lon: 80.903W

Elev: 6

StdP: 101.25

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.2	(c) 1.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 13.0	(k) 7.7	(l) 11.8	(m) 8.8	(n) 6.0	(o) 310	(p) 0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 5.4	(c) 32.8	(d) N/A	(e) 31.7	(f) N/A	(g) 30.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.6	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 11.5	(b) 9.9	(c) 8.6	(e) -3.1	(f) 35.0	(g) 2.3	(h) 0.6	(i) -4.8	(j) 35.5	(k) -6.1	(l) 35.9	(m) -7.4	(n) 36.2	(o) -9.1	(p) 36.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	9.9	11.8	14.3	19.2	23.3	26.8	27.6	27.5	25.4	21.0	14.6	13.0		
	DBStd	7.12	4.63	4.34	4.28	3.16	2.48	1.78	1.42	1.48	2.08	3.18	3.81	4.24		
	HDD10.0	132	59	30	14	1	0	0	0	0	0	0	8	21		
	HDD18.3	917	263	187	136	28	1	0	0	0	0	14	119	170		
	CDD10.0	3620	56	79	146	276	412	503	546	543	461	341	147	113		
	CDD18.3	1364	1	2	9	53	154	253	288	284	211	96	8	4		
	CDH23.3	11637	1	3	19	112	754	2436	3108	3067	1754	373	8	2		
	CDH26.7	3084	0	0	2	7	118	691	978	943	321	26	0	0		
(14) Wind	WSAvg	3.9	4.2	4.1	4.3	4.2	4.0	3.5	3.4	3.4	4.1	4.0	4.2	3.9		
(15) Precipitation	PrecAvg	1202	82	81	90	73	74	135	139	157	121	113	60	74		
	PrecMax	1741	230	275	215	181	194	323	243	392	229	519	138	262		
	PrecMin	822	11	7	6	13	10	34	31	57	19	2	1	19		
	PrecStd	216	57	55	48	47	52	62	55	69	51	99	43	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.7	23.7	25.9	27.8	31.9	33.9	34.0	34.0	31.5	28.7	24.6	23.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	19.4	21.0	23.1	25.8	29.4	32.4	32.6	32.4	30.1	27.4	23.1	21.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	17.8	19.2	21.4	24.7	27.8	31.1	31.4	31.2	29.2	26.3	21.7	20.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	16.3	17.4	19.9	23.6	26.6	30.0	30.5	30.2	28.4	25.4	20.3	18.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCWBR	7.1	7.0	6.8	6.2	5.1	5.7	5.4	5.1	4.5	5.9	6.7	6.6		
		MCWBR	8.2	8.6	8.3	7.1	7.0	7.4	7.1	6.7	5.8	6.3	7.8	7.4		
(40) Clear-Sky Solar Irradiance	taub	taud	0.332	0.340	0.370	0.402	0.451	0.491	0.522	0.505	0.429	0.396	0.357	0.344		
		taud	2.533	2.511	2.445	2.349	2.249	2.190	2.114	2.164	2.371	2.433	2.497	2.524		
	Ebn at Noon	Ebn at Noon	892	919	910	890	844	807	780	788	840	844	855	856		
		Edh at Noon	85	95	109	125	139	147	158	149	116	102	88	82		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.96	3.62	4.76	6.01	6.47	6.43	6.31	5.71	4.81	4.19	3.28	2.63		
	RadStd	RadStd	0.17	0.38	0.44	0.39	0.39	0.48	0.37	0.37	0.41	0.44	0.22	0.21		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	-87	+194	+133	

Nomenclature: See separate page