

OREGON INLET MARINA, NC, USA

WMO: 997307

Lat: 35.7957N

Lon: 75.5482W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.5	29.5	N/A	N/A	N/A	N/A	N/A	N/A	29.2	44.8	26.3	41.9	14.6	320	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.7	(c) 86.3	(d) N/A	(e) 84.9	(f) N/A	(g) 83.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 14.7	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 27.3	(b) 24.8	(c) 22.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	42.8	44.4	48.7	59.4	68.7	76.1	79.1	78.4	74.7	66.1	55.0	49.9		
	DBStd	14.32	8.10	7.26	7.14	6.17	5.82	4.11	3.22	2.67	3.81	5.63	6.66	7.83		
	HDD50	674	243	182	113	4	0	0	0	0	0	0	31	101		
	HDD65	2817	687	576	505	186	34	0	0	0	0	56	303	470		
	CDD50	5072	21	26	74	286	580	783	904	881	740	500	181	96		
	CDD65	1740	0	0	1	18	149	333	439	416	290	91	2	1		
	CDH74	12190	0	0	1	9	416	2436	4163	3526	1537	102	0	0		
	CDH80	2046	0	0	0	0	18	372	919	596	140	1	0	0		
(14) Wind	WSAvg	11.5	11.1	11.6	11.9	12.5	12.3	12.2	12.3	9.9	11.1	11.2	11.3	10.8		
(15) Precipitation	PrecAvg	48.5	3.9	3.1	3.7	2.7	3.2	5.0	5.7	6.2	5.0	3.5	2.5	3.3		
	PrecMax	69.6	7.4	6.5	7.8	7.4	7.1	9.4	10.4	11.7	10.2	8.2	6.9	5.9		
	PrecMin	26.9	1.1	0.9	0.8	0.6	0.0	1.0	1.0	3.0	0.7	0.4	0.0	0.7		
	PrecStd	9.7	1.9	1.6	1.9	2.0	2.1	2.2	2.4	2.5	2.5	2.1	1.8	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.1	64.3	69.9	75.5	82.5	88.6	88.7	87.5	84.5	79.3	70.2	67.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	59.1	60.3	65.8	72.8	79.4	85.3	86.5	85.4	83.0	76.7	68.0	65.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	56.3	57.4	62.2	70.9	77.9	83.6	85.3	84.2	81.7	74.8	66.0	63.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	53.7	54.9	59.6	69.0	76.5	82.2	84.1	83.1	80.4	73.2	64.1	60.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	10.2	9.6	9.7	7.9	7.2	6.7	6.8	5.9	7.5	8.4	9.2		
		MCDBR	13.2	12.6	12.6	10.9	8.6	8.9	7.6	8.2	6.8	7.8	9.8	10.2		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.334	0.356	0.400	0.442	0.484	0.511	0.498	0.420	0.370	0.339	0.332		
	taud		2.531	2.511	2.471	2.354	2.276	2.207	2.143	2.169	2.390	2.513	2.544	2.543		
	Ebn at Noon		277	288	290	281	269	257	249	249	266	272	270	267		
	Edh at Noon		25	29	33	39	43	46	49	46	35	29	25	24		
(44) All-Sky Solar Radiation	RadAvg		752	1003	1347	1717	1933	2047	1921	1756	1457	1171	849	681		
	RadStd		50	101	102	127	135	104	99	119	89	111	59	52		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+286	+196

Nomenclature: See separate page